

H26年7月放射性物質濃度等測定結果

測定日	測定項目								
	焼却主灰中放射性物質濃度 (Bq/kg)			焼却飛灰中放射性物質濃度 (Bq/kg)			焼却炉排ガス中放射性物質濃度 (Bq/m ³)		
	3号炉			3号炉			3号炉		
	¹³⁴ Cs	¹³⁷ Cs	合計	¹³⁴ Cs	¹³⁷ Cs	合計	¹³⁴ Cs	¹³⁷ Cs	合計
1	160	450	610	—	—	—	ND	ND	ND
2	160	480	640	600	1,780	2,380	ND	ND	ND
3	180	530	710	900	2,580	3,480	ND	ND	ND
4	—	—	—	—	—	—	—	—	—
5	—	—	—	—	—	—	—	—	—
6	—	—	—	—	—	—	—	—	—
7	—	—	—	—	—	—	—	—	—
8	—	—	—	—	—	—	—	—	—
9	—	—	—	—	—	—	—	—	—
10	—	—	—	—	—	—	—	—	—
11	—	—	—	—	—	—	—	—	—
12	—	—	—	—	—	—	—	—	—
13	—	—	—	—	—	—	—	—	—
14	—	—	—	—	—	—	—	—	—
15	—	—	—	—	—	—	—	—	—
16	—	—	—	—	—	—	—	—	—
17	—	—	—	—	—	—	—	—	—
18	—	—	—	—	—	—	—	—	—
19	—	—	—	—	—	—	—	—	—
20	—	—	—	—	—	—	—	—	—
21	—	—	—	—	—	—	—	—	—
22	—	—	—	—	—	—	—	—	—
23	—	—	—	—	—	—	—	—	—
24	—	—	—	—	—	—	—	—	—
25	—	—	—	—	—	—	—	—	—
26	—	—	—	—	—	—	—	—	—
27	—	—	—	—	—	—	—	—	—
28	—	—	—	—	—	—	—	—	—
29	—	—	—	—	—	—	—	—	—
30	—	—	—	—	—	—	—	—	—
31	—	—	—	—	—	—	—	—	—
特記事項									