

H26年9月放射性物質濃度等測定結果

測定日	測定項目								
	焼却主灰中放射性物質濃度 (Bq/kg)			焼却飛灰中放射性物質濃度 (Bq/kg)			焼却炉排ガス中放射性物質濃度 (Bq/m ³)		
	3号炉			3号炉			3号炉		
	¹³⁴ Cs	¹³⁷ Cs	合計	¹³⁴ Cs	¹³⁷ Cs	合計	¹³⁴ Cs	¹³⁷ Cs	合計
1	—	—	—	—	—	—	—	—	—
2	—	—	—	—	—	—	—	—	—
3	—	—	—	—	—	—	—	—	—
4	—	—	—	—	—	—	—	—	—
5	—	—	—	—	—	—	—	—	—
6	—	—	—	—	—	—	—	—	—
7	—	—	—	—	—	—	—	—	—
8	—	—	—	—	—	—	—	—	—
9	—	—	—	—	—	—	—	—	—
10	—	—	—	—	—	—	—	—	—
11	—	—	—	—	—	—	—	—	—
12	—	—	—	—	—	—	—	—	—
13	—	—	—	—	—	—	—	—	—
14	—	—	—	—	—	—	—	—	—
15	180	530	710	—	—	—	ND	ND	ND
16	130	410	540	540	1600	2140	ND	ND	ND
17	140	420	560	530	1630	2160	ND	ND	ND
18	130	420	550	550	1710	2260	ND	ND	ND
19	140	440	580	500	1490	1990	ND	ND	ND
20	210	560	770	500	1550	2050	ND	ND	ND
21	110	360	470	630	1980	2610	ND	ND	ND
22	180	550	730	750	2230	2980	ND	ND	ND
23	210	690	900	710	2200	2910	ND	ND	ND
24	220	680	900	750	2310	3060	ND	ND	ND
25	160	500	660	620	1980	2600	ND	ND	ND
26	210	610	820	690	2240	2930	ND	ND	ND
27	190	560	750	660	2100	2760	ND	ND	ND
28	160	500	660	690	2170	2860	ND	ND	ND
29	100	320	420	560	1730	2290	ND	ND	ND
30	—	—	—	—	—	—	—	—	—
31									
特記事項									