

H26年 2月放射性物質濃度測定結果

測定日	測定項目																										
	焼却主灰中放射性物質濃度(Bq/kg)									焼却飛灰中放射性物質濃度(Bq/kg)									焼却炉排ガス中放射性物質濃度(Bq/m ³)								
	1号炉			2号炉			3号炉			1号炉			2号炉			3号炉			1号炉			2号炉			3号炉		
	¹³⁴ Cs	¹³⁷ Cs	合計	¹³⁴ Cs	¹³⁷ Cs	合計	¹³⁴ Cs	¹³⁷ Cs	合計	¹³⁴ Cs	¹³⁷ Cs	合計	¹³⁴ Cs	¹³⁷ Cs	合計	¹³⁴ Cs	¹³⁷ Cs	合計	¹³⁴ Cs	¹³⁷ Cs	合計	¹³⁴ Cs	¹³⁷ Cs	合計	¹³⁴ Cs	¹³⁷ Cs	合計
1	220	580	800	250	650	900	560	1,480	2,040	680	1,650	2,330	560	1,370	1,930	4,190	10,520	14,710	-	-	-	-	-	-	ND	ND	ND
2	240	620	860	230	610	840	620	1,580	2,200	500	1,260	1,760	480	1,200	1,680	1,850	4,560	6,410	-	-	-	-	-	-	ND	ND	ND
3	310	750	1,060	270	650	920	250	650	900	560	1,410	1,970	550	1,390	1,940	1,420	3,670	5,090	-	-	-	-	-	-	ND	ND	ND
4	250	640	890	260	660	920	560	1,350	1,910	560	1,420	1,980	590	1,490	2,080	2,530	6,440	8,970	-	-	-	-	-	-	ND	ND	ND
5	260	670	930	320	780	1,100	290	720	1,010	550	1,330	1,880	650	1,640	2,290	1,900	4,840	6,740	-	-	-	-	-	-	ND	ND	ND
6	310	750	1,060	280	740	1,020	410	960	1,370	620	1,540	2,160	640	1,630	2,270	1,720	4,370	6,090	-	-	-	-	-	-	ND	ND	ND
7	290	750	1,040	300	740	1,040	280	760	1,040	550	1,390	1,940	580	1,480	2,060	1,500	3,830	5,330	-	-	-	-	-	-	ND	ND	ND
8	240	660	900	290	720	1,010	560	1,420	1,980	500	1,340	1,840	540	1,420	1,960	2,230	5,670	7,900	ND	ND	ND	ND	ND	ND	ND	ND	ND
9	280	660	940	290	740	1,030	210	470	680	470	1,210	1,680	510	1,240	1,750	1,640	4,160	5,800	-	-	-	-	-	-	ND	ND	ND
10	-	-	-	300	780	1,080	190	460	650	-	-	-	520	1,340	1,860	1,440	3,810	5,250	-	-	-	-	-	-	ND	ND	ND
11	-	-	-	330	850	1,180	70	210	280	-	-	-	610	1,590	2,200	870	2,240	3,110	-	-	-	-	-	-	ND	ND	ND
12	-	-	-	270	690	960	140	340	480	-	-	-	620	1,620	2,240	980	2,570	3,550	-	-	-	-	-	-	ND	ND	ND
13	-	-	-	360	950	1,310	150	340	490	-	-	-	610	1,540	2,150	1,300	3,350	4,650	-	-	-	-	-	-	ND	ND	ND
14	-	-	-	360	920	1,280	160	420	580	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	ND	ND	ND
15	-	-	-	300	810	1,110	250	620	870	-	-	-	450	1,110	1,560	1,200	3,110	4,310	-	-	-	-	-	-	ND	ND	ND
16	-	-	-	270	670	940	230	580	810	-	-	-	360	890	1,250	1,520	3,950	5,470	-	-	-	-	-	-	ND	ND	ND
17	-	-	-	270	680	950	180	460	640	-	-	-	440	1,110	1,550	1,990	5,070	7,060	-	-	-	-	-	-	ND	ND	ND
18	-	-	-	330	820	1,150	70	190	260	-	-	-	600	1,590	2,190	1,400	3,410	4,810	-	-	-	-	-	-	ND	ND	ND
19	-	-	-	210	540	750	220	550	770	-	-	-	680	1,750	2,430	1,930	4,830	6,760	-	-	-	-	-	-	ND	ND	ND
20	-	-	-	290	740	1,030	260	680	940	-	-	-	650	1,680	2,330	2,000	5,160	7,160	-	-	-	-	-	-	ND	ND	ND
21	-	-	-	310	800	1,110	350	890	1,240	-	-	-	730	1,930	2,660	2,230	5,770	8,000	-	-	-	-	-	-	ND	ND	ND
22	-	-	-	310	840	1,150	210	550	760	-	-	-	700	1,830	2,530	1,890	4,610	6,500	-	-	-	-	-	-	ND	ND	ND
23	-	-	-	290	750	1,040	340	880	1,220	-	-	-	720	1,880	2,600	2,870	7,120	9,990	-	-	-	-	-	-	ND	ND	ND
24	-	-	-	310	790	1,100	220	570	790	-	-	-	660	1,690	2,350	1,230	3,240	4,470	-	-	-	-	-	-	ND	ND	ND
25	-	-	-	300	800	1,100	360	900	1,260	-	-	-	680	1,740	2,420	1,950	5,010	6,960	-	-	-	-	-	-	ND	ND	ND
26	-	-	-	310	830	1,140	520	1,320	1,840	-	-	-	760	2,030	2,790	2,210	5,530	7,740	-	-	-	-	-	-	ND	ND	ND
27	-	-	-	280	730	1,010	700	1,850	2,550	-	-	-	640	1,810	2,450	1,720	4,310	6,030	-	-	-	-	-	-	ND	ND	ND
28	-	-	-	310	740	1,050	190	490	680	-	-	-	640	1,690	2,330	640	1,680	2,320	-	-	-	-	-	-	ND	ND	ND
-																											
-																											
-																											

特記事項 * 13日: 11:45工業用水配管破損のため、2,3号炉立下げ
 14日: 14:30工業用水配管復旧工事完了 立上げ開始(2,3号炉:焼却飛灰中放射性物質濃度測定なし)

(ND: 検出下限値[ろ紙部、ドレン部のセシウム134、セシウム137濃度が各2Bq/m³(N)]未満)