

Feasibility Studies on Joint Crediting Mechanism Projects towards
Environmentally Sustainable Cities in Asia

Strategic Promotion of Recovery and Destruction of
Fluorocarbons
(English)

March 2015

E&E Solutions Inc.

Contents

Chapter 1	Outline of the Study	1
1.	Implementation Policies and Objectives of the Survey	2
1.1	Implementation policies and objectives of the overall project	2
1.2	Survey implementation structure	2
Chapter 2	Results of the Study in Thailand	3
1.	Overview of the Target Country	4
1.1	Measures against climate change.....	4
1.2	Fluorocarbon measures	6
2.	Fact-finding Survey in Industrial Facilities.....	8
2.1	Overview of the fact-finding survey	8
2.2	Fact-finding survey.....	9
3.	Survey on Prevalence of Energy Saving Equipment at Commercial Facilities... 10	
3.1	Overview of the survey	10
4.	Study on Recovery of Fluorocarbons and Collection of Fluorocarbon-Containing Equipment.....	11
4.1	Current situation of recovery of fluorocarbons and collection of fluorocarbon-containing equipment	11
4.2	Study on proper disposal of fluorocarbons and fluorocarbon-containing equipment....	11
4.3	Study on logistics of fluorocarbons and fluorocarbon-containing equipment.....	13
5.	Survey on Fluorocarbon Destruction.....	14
5.1	Current situation of fluorocarbon destruction.....	14
5.2	Study on fluorocarbon destruction.....	14
6.	Study on Collection System	17
7.	Confirmation of Project Implementation Structure and Finance Scheme.....	19
7.1	Japanese food manufacturer.....	19
7.2	Convenience store	22
8.	Examination of MRV Methodologies	27
8.1	Japanese food manufacturer.....	27
8.2	Convenience store	30
8.3	Evaluation methods of fluorocarbon destruction effects.....	35
Chapter 3	Results of the Study in Malaysia	37
1.	Overview of the Target Country	38
1.1	Measures against climate change.....	38
1.2	Fluorocarbon measures	40
2.	Fact-Finding Survey of Energy Saving Equipment Use.....	43

2.1	Overview of the survey	43
2.2	Questionnaire survey	43
2.3	Fact-finding survey.....	44
3.	Study on Logistics and Collection of Fluorocarbons	48
3.1	Current situation of recovery of fluorocarbons.....	48
3.2	Current situation of destruction of fluorocarbons	48
4.	Study of Collection system	51
5.	Examination of Implementation Structure and Finance Scheme.....	52
5.1	National hospital (M-1).....	52
5.2	Commercial facility (M-2)	55
5.3	University (M-3)	57
6.	Examination of MRV Methodologies	59
6.1	Examination of MRV Methodologies.....	59
6.2	Evaluation methods of fluorocarbon destruction effects	60

Chapter 1 Outline of the Study

1. Implementation Policies and Objectives of the Survey

1.1 Implementation policies and objectives of the overall project

The aim of the feasibility studies on large-scale JCM (Joint Crediting Mechanism) projects is to establish environmentally sustainable cities in Asia by discovering and forming GHG emissions reduction projects in a large scale.

The refrigerant is used in the refrigeration and air conditioning system among high-power consumption equipment that are installed at commercial facilities and plants of some sectors (food manufacturing, etc.). In Southeast Asian countries including Thailand and Malaysia, fluorocarbons such as CFC, HCFC and HFC that have a high global warming potential are mainly used. Even if such equipment is replaced with an energy saving one and energy consumption is reduced, discharge of refrigerant with a high global warming potential may offset the energy-saving effects. Also, discharge of CFC and HCFC in the conventional equipment is not recommendable for ozone layer protection. However, no system to properly treat fluorocarbons in end-of-life equipment has been well established in Southeast Asian countries. Against the backdrop, it is critical to establish a proper refrigerant recovery and destruction system while reducing energy consumption by replacing the equipment.

1.2 Survey implementation structure

The Project was carried out jointly by E&E Solutions Inc., Dowa Eco-System Co., Ltd., and the Institute for Global Environmental Strategies. The energy-efficiency diagnosis was performed in collaboration with NTT Data Institute of Management Consulting, Inc., and NTT GP-ECO Communications Inc. Understanding of local situations and coordination among relevant local parties was performed in collaboration with Waste Management Siam (WMS) (Thailand) and Universiti Teknologi Malaysia (Malaysia).

Chapter 2 Results of the Study in Thailand


1. Overview of the Target Country

1.1 Measures against climate change

1.1.1 Greenhouse gas (GHG) emissions

(1) Trend of CO₂ emissions

The CO₂ emissions in Thailand are shown in Figure 2.1.1. It illustrates the increase in the emissions in line with economic growth. By sector, three sectors—electricity and heat-derived, industrial, and transportation—account for a large portion of emissions. Equipment that uses fluorocarbons (such as chillers and air conditioning systems), that are the target of the study, consumes much electricity and curbing their power consumption is critical as it contributes to CO₂ emissions reduction in Thailand.




Source: Compiled based on IEA (International Energy Agency) data

Figure 2.1.1 Trend of CO₂ Emissions in Thailand

(2) Trend by power source

The electricity sector accounts for more than 30% of CO₂ emissions in Thailand and the trend of power generation by power source (fuel) is summarized in Figure 2.1.2. Natural gas accounts for approximately 70% of power generation and coal accounts for 20%. The grid emission factor shows that low-carbon dependence of electricity has been in progress recently in the country. When compared with that in 2010, the ratio of natural gas-fired power generation increased and coal-fired power generation decreased after 2012. In consideration of this, the CO₂ emission basic units believed to have improved, compared with the figures announced by the government in 2010.



Data source: IEA

Figure 2.1.2 Trend of Electric Power Generation by Power Source in Thailand

1.1.2 Low-carbon policies

(1) Overview of energy-saving policies in Thailand

The Ministry of Energy is responsible for energy policies including electricity of Thailand and the Department of Alternative Energy Development and Efficiency (DEDE) and other departments are established under the ministry to manage energy-saving measures.

The Energy Conservation Promotion Act that was enacted in 1992 (revised in 2005) serves as the foundation of Thai energy policies. Policies under the act are divided into the Energy Conservation (ENCON) Programs and the Demand Side Management (DSM) Programs.

The ENCON includes financial support for energy-saving measures, support for technologies of energy saving and renewable energies and promotion of their prevalence, technological development and instructions, and publicity of energy conservation promotion. The DSM is divided into two phases: the first phase from 1993 to 1998 and the second from 2002 to 2006. The second phase mainly includes support for load adjustment technologies for SMEs, standardization of energy use, labeling of energy efficiency and public-private partnership (ESCO projects) in addition to conventional energy conservation promotion.

(2) Low-carbon policies

Thailand Greenhouse Gas Management Organization (TGOI) is responsible for the examination of low-carbon policies of the country. It has been working on the establishment of the Thailand Voluntary Emission Reduction Program (T-VER) in recent years in order particularly to set up the domestic carbon market. T-VER is a program to certify voluntary GHG emission reduction efforts


within Thailand and it was set up with J-VER as a model and introduced by the Thai Government in October 2013.

According to the interview with TGO (September 19, 2014), the main target of T-VER is energy-derived GHG and the target gases are CO₂, CH₄ and N₂O. HFC and other fluorocarbons that are designated under the Kyoto Protocol are not included, which makes it difficult for Thai business operators to regard their reduction as direct Co-Benefit. On the other hand, they believe that technical transfer of fluorocarbon recovery and destruction and its contribution to its domestic economy is attractive as Co-Benefit. In this sense, the recovery and destruction scheme of R22, etc., that is much contained in old equipment is likely to be considered as Co-Benefit in the country.

1.2 Fluorocarbon measures

1.2.1 Flow of fluorocarbons used as refrigerant

The flow of fluorocarbons that are used as refrigerant is shown below. It is assumed that manufacturers (particularly Japanese manufacturers) keep or partially destroy the used refrigerant that is discharged in the manufacturing process on their premises under their own responsibility. On the other hand, the refrigerant contained in equipment during its use is often managed by the distributors and maintenance service providers and sections. However, it is believed that most of fluorocarbons in end-of-life equipment go to informal flow.



Source: Compiled based on interview results

Figure 2.1.3 Flow of Fluorocarbons Used as Refrigerant

1.2.2 Relevant regulations

Fluorocarbons are regulated as hazardous substances or hazardous waste in Thailand and thus the related regulations are applied. For example, fluorocarbons are required to be destroyed at incineration facilities of hazardous waste, which differs Japanese or Malaysian situations.

As for fluorocarbons used as refrigerant of products in the manufacturing process, the volume of imports, storage and usage is managed under the Notification of MOI B.E.2546 List of Hazardous Substances under the Hazardous Substance Act B.E.2535 under the jurisdiction of the Pollution Control Department (PCD) of the Ministry of Natural Resources and Environment. When they are discharged for disposal, they are controlled by the manifest based on the Notification of MOI on Disposal of Wastes or Unusable Materials B.E. 2548 (2005) under the Factory Act under the jurisdiction of the Ministry of Industry. On the other hand, although fluorocarbons used as refrigerant in end-of-life equipment are designated as hazardous substances, there is no requirement related to recovery or disposal of fluorocarbons.

End-of-life equipment is managed under the Public Sanitation Act if it is discharged from household (including commercial facilities) and local governments are responsible for waste disposal. Waste from industrial facilities is managed under the Factory Act.

The competent authority under the Montreal Protocol and Basel Convention is DIW (PCD is the focal point.) and the Ozone Protection Unit of the DIW is in charge of matters related to the protocol. In relation to the permits for destruction and exports of fluorocarbons, the Ozone Protection Unit serves as a reference for opinions based on the protocol. The Industrial Waste Management Bureau of the DIW is in charge of it based on the Factory Act and the Hazardous Waste Act.

2. Fact-finding Survey in Industrial Facilities

2.1 Overview of the fact-finding survey

We conducted fact-finding survey in Bangpoo Industrial Estate, mainly focusing on food manufacturing plants where energy consumption for refrigeration is high. We conducted questionnaire survey about the facilities they own and walk-through survey to understand the facility conditions.




Figure 2.2.1 Flow of Fact-Finding Survey

We obtained responses of the questionnaire from 7 plants in the Bangpoo Industrial Estate. We compared the results about the following indicators and selected potential facilities for a JCM project:

<Selection criteria>

- ◆ Freezers were installed many years ago. (There will be much room for energy saving.)
- ◆ Relatively big scale.
- ◆ Have interest in replacement.


We selected one food manufacturing facility as potential facility based on the above selection criteria and conducted survey.

2.2 Fact-finding survey

(1) Interview survey results

We confirmed the following in interview survey:

- It has interest in the JCM financing program by the Ministry of Environment.
- It uses R-22 for the compressor of the facility and is considering changing refrigerant type as its use is prohibited in the future.
- Four of five compressors are 75kW and the compressors are 24-hour operation when the plant is in operation. However, it operates only one unit on holidays.
- It needs to replace the compressor and indoor equipment together when it changes the refrigerant type.
- It will replace them when it suspends the operation during Thai new year holidays and other long suspension period.

	
Container refrigerator	Refrigeration compressor
	
Refrigerant storage cylinder	Outdoor unit for air conditioning system (made in Thailand)

3. Survey on Prevalence of Energy Saving Equipment at Commercial Facilities

3.1 Overview of the survey

We chose FamilyMart as the target of the survey on commercial facilities. Thai FamilyMart launched their efforts to be eco-friendly stores around 2011¹. For example, they used showcases with HCFC (R22) as the refrigerant until 2011. However, they have been using showcases with HFC (R410A) since 2011.

FamilyMart is estimated to have approximately 800 stores in Bangkok and its surrounding areas. Their locations can be largely divided as in the table below. We selected target stores that are classified as such in the table below to study their actual situation.

Table 2.3.1 Selection of Target FamilyMart Stores of the Survey

Classification	Overview	Target
① Central area	Located in the center of Bangkok on the first floor of a multitenant building. The floor area is relatively small.	Sukhumvit 48 Floor area: 60.5 m ² 
② Surrounding area	Although situated on the first floor of a multitenant building, the floor area is bigger than that of ① because it is slightly away from central Bangkok.	Sukhumvit 95/1 Floor area: 76 m ² 
③ Suburb	Situated slightly away from central Bangkok. Many of them are one-story building.	Wat Bangnanai Floor area: 82 m ² 

Source: NTT Data Institute of Management Consulting

¹ Estimated based on interview with relevant parties

4. Study on Recovery of Fluorocarbons and Collection of Fluorocarbon-Containing Equipment

4.1 Current situation of recovery of fluorocarbons and collection of fluorocarbon-containing equipment

Although there are numerous facilities of waste sorting, landfilling or reuse and recycling in Thailand, there are very few large-scale recyclers that dismantle equipment and they basically handle IT device including valuable resources. The government offers no regular engineer training on fluorocarbon recovery, although it has provided several sessions in the past.

ESBEC was built as a final landfill facility for non-hazardous waste in 2000 and has disposed of more than 1 million tons of waste by landfill. It began recycling WEEE in 2010 in response to the request from IT manufacturers. It uses know-how of DOWA Group. Although it began to dismantle freezers used by foreign food manufacturers at convenience stores several years ago, the manufacturers recover the fluorocarbons by themselves.

4.2 Study on proper disposal of fluorocarbons and fluorocarbon-containing equipment

We performed fluorocarbon recovery test and fluorocarbon-containing equipment dismantle test at ESBEC in order to acquire proper fluorocarbon recovery technology and understand the cost of the recovery and dismantle. The testing methods and test results are summarized below.

4.2.1 Fluorocarbon recovery test

(1) Recovery test method

- Test site: ESBEC (DOWA Group's waste disposal facility)
- Target equipment: 5 ice cream freezers at convenience stores (provided by the manufacturer for testing)
- Fluorocarbon recovery method: Performed based on Japanese relevant guidelines and practices at Japanese recycling facilities. Japan-based supplier of the equipment supported by giving instructions.

※The compressors oil was not removed because the recovery machine with no oil separator was used in the fluorocarbon recovery test in the Project.

- Data to be recorded: The data below was recorded in the fluorocarbon recovery tests.
 - Time required
 - Weight of freezers before and after recovery (estimate the amount of removed refrigerant)
 - Weight of cylinders before and after recovery (estimate the amount of recovered refrigerant)

(2) Test results

The fluorocarbon recovery test results of five target units are summarized below. The average weight of recovered refrigerant is 130g to 140kg per unit, the average time required for the recovery is approximately 13 minutes, and the average recovery rate is 93%. When no recovery of the compressor oil is considered (the oil contains some dissolved fluorocarbons), the recovery rate is relatively high.

Obtaining the results, including the reflection of Japanese knowledge on recovery, it was the first step towards the realization of proper recovery methods in Thailand. When it is continued to be implemented in a future Project, it will contribute to proper fluorocarbon management in Thailand through further improvement by such efforts as dispatch of Japanese experts.

Table 2.4.1 Fluorocarbon Recovery Test Results

Freezer ID	Refrigerant type	Time required (min)	Cylinder weight difference before and after recovery (kg) ①	Freezer weight difference before and after recovery (kg) ②	Recovery rate (%) (①÷②)
1	R134a	12	0.08	0.08	100
2	R134a	10	0.16	0.18	89
3	R134a	22	0.12	0.12	100
4	R134a	14	0.16	0.16	100
5	R134a	11	0.12	0.16	75
Average	-	13	0.13	0.14	93

4.2.2 Fluorocarbon-containing equipment dismantle test

(1) Equipment to be dismantled

- Test site: ESBEC (DOWA Group's waste disposal facility)
- Target equipment: Equipment from which fluorocarbons are recovered in recovery tests
- Dismantle test method: The company workers dismantle fluorocarbon-containing equipment in regular operation.
- Data to be recorded: The data below was recorded in the fluorocarbon-containing equipment dismantle tests.
 - Time required
 - Weight of valuable resource (recyclable metal, etc.)
 - Weight of waste (landfall or incinerated)

(2) Dismantle test results

As a result of dismantle of five target units, it required an average of 20 minute per unit and approximately 85% of the freezers in weight was recovered as valuable resource.

Table 2.4.2 Fluorocarbon-Containing Equipment Dismantle Test Results

Freezer ID	Time required (min)	Weight of valuable resource (kg)				Waste weight (kg)	
		Steel	Aluminum + plastic	Copper pipe	Compressor	Insulator	Refrigerant
1	15	30.8	3.5	4.9	10.8	6.1	0.08
2	25	30.5	1.7	3	12	10.3	0.16
3	25	27	1.4	2.9	11.9	9	0.12
4	15	36.8	-	5.4	9.5	8.1	0.16
5	22	32.1	-	4.7	11.2	7	0.12
Average	20	31.4	1.3	4.2	11.1	8.1	0.13

4.3 Study on logistics of fluorocarbons and fluorocarbon-containing equipment

WMS of DOWA Group has transfer stations of waste across Thailand. It also set up transport bases (collection base) in each region for efficient waste collection. There are four bases: NTS in the northern region (Chingmai), LTS in the central region (Lad Krabang), ATS in the eastern region (Amata Nakorn), and STS in the southern region (Songkla). In the future, the collection network can be used to collect end-of-life equipment and transport it to ESBEC where fluorocarbons are removed and end-of-life equipment is dismantled.

5. Survey on Fluorocarbon Destruction

5.1 Current situation of fluorocarbon destruction

There are two facilities that perform fluorocarbon destruction in Thailand. The only one hazardous waste incineration facility in the country has performed the destruction on the commercial basis and an air conditioning system manufacturer performs it in-house in their plant.

5.1.1 Hazardous waste incineration facility

Akkhie Prakarn Public Company Limited is established in Bangpoo Industrial Estate, led by DIW, for disposing of hazardous waste in Thailand. It is the only one hazardous waste incineration facility in the country. It is the only one facility that is licensed to commercially destroy fluorocarbons that are brought in from outside.

5.1.2 In-house disposal facility of a Japanese manufacturer

The manufacturer originally examined fluorocarbon destruction at an existing incineration facility and conducted destruction tests at the facility introduced by the government. However, it refused continuous destruction because of the damage to the furnace and odor. It then introduced in-house hydrolytic destruction facility. It mainly destroys fluorocarbons that are discharged in repairing off-spec products produced on the plant line and fluorocarbons that are discharged every morning in the inspection of refrigerant filling machine. With the current permission, it is allowed to perform fluorocarbon destruction it generates in-house and it is not permitted to accept fluorocarbons from external companies or plants or destroy them.

5.2 Study on fluorocarbon destruction

5.2.1 Destruction in existing facilities

Fluorocarbons defined as hazardous waste can be disposed of in the hazardous waste incineration facility in Bangpoo Industrial Estate in Thailand. Further consultations are needed to involve the facility in the Project, in order to guarantee traceability and examine the GHG reduction capacity in relation to the fluorocarbon destruction of the Project.

5.2.2 Other options of fluorocarbon destruction

(1) Existing waste disposal facility

BPEC of DOWA Group is one of incineration facilities in Thailand and it started as NEDO's model facility project for effective use of waste from industrial estates in Thailand. The incinerator is a fluid bed furnace with the daily capacity is 100 tons. Although it was originally operated based on the US (Waste Management) standards, DOWA Ecosystem purchased the holding company. It is licensed to incinerate non-hazardous waste only. In the Japanese classification, it is allowed to

dispose of general business waste and industrial waste (excluding the specially controlled waste). The facility operation rate has increased since it became a DOWA Group company and there is almost no facility that maintains such a high operation rate stably in Thailand. Although there remains the licensing issue, it can be a candidate site of practicing fluorocarbon destruction using Japanese technologies and operational know-how.

The following was conducted in the Project with the assumption of future destruction by BPEC and destruction tests for it:

<Matters related to fluorocarbon destruction tests at BPEC>

- IEAT director needs to decide whether to permit the destruction tests at BPEC based on opinions of the DIW.
- In order to submit a proposal to IEAT, provide ① information on Japanese regulations and guidelines, ② data of facilities that are actually in operation in Japan, and ③ information on environmental impacts to be caused by the tests.
- An outline of the destruction tests at BPEC was considered as follows:
 - Destruction time: approximately 6 hours in total
 - Destruction volume (for testing): destroy approximately 120kg of fluorocarbons in total.
 - Additional facility and cost: piping and other equipment, flow meter, and installation cost, etc.
 - Note: It is desirable that engineers be dispatched from Japan for exhaust gas analysis.

(2) Cement company

The cement company we interviewed in the Project does not perform fluorocarbon destruction and we did not see their intension of performing it in the future. It accepts and uses wastes as alternative materials and fuels not as waste disposal and it plans to enhance RDF use in the near future.

(3) Other options

Other options of destruction include introduction of portable fluorocarbon destruction facility and destruction by importing in Japan. Their outline and problems related to each options are summarized below.

a) Portable fluorocarbon destruction facility (example of a manufacturer)

- ✓ Past overseas delivery of portable dissolution unit: 1 unit each in Argentina, Ecuador and China
- ✓ Destruction in other countries: unknown (because involved only in facility introduction)
- ✓ Problems related to overseas development:
 - No laws or regulations on fluorocarbon destruction in the target country

- High installation cost (over 10 million yen per unit with no subsidy)
- Low destruction capacity (2kg per hour in standard (approximately 3 air-conditioners)) (5 tons per year if operated 2,400 hours a year)
- Although it is portable, connection with various utilities is required and it cannot be moved or operated easily.

b) Imports to Japan for destruction

- ✓ They cannot be imported to Japan for destruction because of the ozone layer protection law. (no provision in the law)
- ✓ Although imports for testing or use as raw materials are allowed as special cases, the surplus is returned to the origin, not being destroyed in Japan.

DIW staff who attended the later mentioned workshop that was organized under the project made the following comments on the imports:

- ✓ Is it possible to export used fluorocarbons from Thailand to Japan to have them destroyed there?
- ✓ Although they can be destroyed at hazardous waste disposal facility in Thailand, they see the advantage of quick disposal in Japan where there are many destruction facilities (and destruction capacity).

Although there seems to be demand for fluorocarbon destruction in Thailand and imports will remain as an alternative to domestic destruction, there are problems related to imports to Japan as described above. And its exports (not limited to Japan) from Thailand were examined as literature² shows and it was not realized because of import and export procedural problems including the procedures under the Basel Convention because they are hazardous waste. Agreements on intergovernmental cooperation on fluorocarbon exports and imports will be needed for its realization.

²International survey on CFC distribution and its recovery and destruction methods (March 2013), Nomura Research Institute, Ltd.

6. Study on Collection System

The important of fluorocarbons collection system is sustainability and traceability the systems. In the Project, packaging with replacement of energy saving equipment can be incentives to the recovery and destruction of fluorocarbon. Thus, the problem is the availability of and collaboration with players equipped with proper technologies. As shown in the table below, collaboration is possible in each step of the collection system.

Table 2.6.1 Options of Recovery System in Thailand

Steps of Recovery System	Options Available in the Project
Collection of end-of-life equipment from the site	WMS's transport network is available.
Recovery of used fluorocarbons	Can be performed at ESBEC (technical collaboration with Japan is to be continued.)
Dismantle of end-of-life equipment	Can be performed at ESBEC.
Fluorocarbon reclamation	No fluorocarbon reclamation operator recommended by the government is confirmed in the Project.
Fluorocarbon destruction	Seeks continued consultation with hazardous waste incineration facility and possibility of destruction tests at BPEC.


Although it is difficult to secure fluorocarbon destruction facility that satisfies all of the requirements of the Project, hazardous waste incineration facility can be used for destruction under the local standards. The table below summarizes the examination results of fluorocarbon destruction facility.

Table 2.6.2 Fluorocarbon Destruction Facility in Thailand

	Survey Results	Availability	Traceability
Existing facility	Waste incineration facility (hazardous): The only one facility that is licensed to destroy fluorocarbons on the commercial basis can be used. However, the destruction condition and traceability need to be confirmed.	○	△
	In-house disposal facility: Although a Japan-based manufacturer has introduced fluorocarbon disposal facility for its own plant, it is not allowed to accept the substance from outside.	×	-
Other options of fluorocarbon destruction	Waste disposal facility (non-hazardous): DOWA Group has a non-hazardous waste incineration facility (BPEC). It needs to obtain a license for hazardous waste to destroy fluorocarbons that are hazardous.	△ Confirm procedures of destruction tests.	○
	Cement company: It has no interest in fluorocarbon destruction.	×	-
	Portable facility: When the introduction cost is taken into consideration, there is no fluorocarbon disposal program and thus the cost is not covered by subsidies, etc., and thus it is difficult to introduce it in the country.	×	-
	Imports to Japan: Under the current situation, it is difficult because of import procedures of Japan side.	×	-

7. Confirmation of Project Implementation Structure and Finance Scheme

We examined energy saving equipment introduction projects as shown below based on the survey results in Thailand described above. The “Financing Program for JCM Model Project” of the Ministry of Environment is assumed to be used because of the nature of the possible scheme and target equipment. Thus, “Financing Program” below refers to the “Financing Program for JCM Model Project” of the Ministry of Environment.



Source: Recent Development of The Joint Crediting Mechanism (JCM), January 2015

Figure 2.7.1 Financing Program for JCM Model Project

7.1 Japanese food manufacturer

7.1.1 Project overview

(1) Tentative schedule

Based on the fact-finding survey, compressors for the refrigeration system (75kW × 5 units, 55kW × 1 unit) can be the target facility of the JCM project. In consideration of the current facility layout, it will be difficult to replace all the six compressors individually and thus it is realistic to suspend the operation of the entire plant to replace all of them at once. The replacement plan needs to be formulated in accordance with the plant operation schedule.

Table 2.7.1 Project Schedule (Proposal) (T-1)

Time	Contents
FY2014	Proposal of outline of energy-efficiency improvement
FY 2015 or later Year 1	PS implementation ➤ Adjustment of details of equipment specifications ➤ Formulation of facility replacement plan in line with the plant operation schedule
Year 2	Facility replacement ➤ Replacement of compressors and motors ➤ Assumed to be replaced with equipment that contains HFC R404A refrigerant
Year 3	Monitoring ➤ Monitoring of energy consumption, etc.

(2) Main technologies to be introduced and project cost**【Efficiency improvement of compressors for refrigeration system】**

- The existing refrigeration system uses HCFC-22. Since it is a concentrated heat source, the compressor needs to be in operation even during partial operation. Even when the number of units in operation is controlled for energy saving, the rated power consumption of the individual compressor is large.
- Individually packaged refrigeration units are installed in individual refrigerating rooms and it is operated in line with the use of each room. This will not require power that will be wasted. As recent models are equipped with inverters and are highly efficient, they can be operated with less energy than existing systems.
- As for the project cost, the introduction of energy saving facility is estimated to be an average of 11 million yen per system based on the interview survey with facility suppliers under the condition that the equipment is introduced to the facility. Since 20 systems are considered to be introduced, the total project cost is estimated to be 220 million yen.
- In order to introduce the system and apply to Financing Program, equipment of Japanese manufacturer needs to be available. However, none of several Japanese manufacturers we interviewed with have introduced the system in Thailand.

(2) Main technologies to be introduced and project cost




Figure 2.7.2 Image of Freezer Introduction

(3) Implementation structure

The project implementation structure is provided in the figure below. Entities and their roles in the figure are currently under coordination and the scheme herein is a tentative.

The verification of fluorocarbon recovery and destruction is also an important element of the Project.




Figure 2.7.3 Tentative Project Implementation Structure (T-1)

7.1.2 CO₂ reduction

The CO₂ reduction after the replacement with energy saving equipment based on the technology introduced in 7.1.1 is estimated as below.

- **Contents of Replacement**

One refrigeration system of compressor 75kW × 4 units and 55kW × 1unit to be replaced by individual refrigeration unit

- **Annual Reduction of Power Consumption**


Reference annual CO₂ reduction: 324 t-CO₂/Year

- **GHG Reduction by HFC Destruction**

462kg (5unit) × 1,300 = 600 t-CO₂

- **Approximate Investment Cost**

220,000,000 Yen



7.2 Convenience store

7.2.1 Project overview

(1) Tentative schedule

The T-2 project schedule is examined for both replacement of facility at the refurbishment of stores and introduction of facility to new stores. As described earlier, Thai FamilyMart began efforts to transform themselves into eco-friendly stores in 2011 and refrigeration showcases with HFC as the refrigerant have been introduced to new stores that opened after 2011. As of 2014, the ratio of HCFC to HFC (based on the number of stores) is estimated to be 6 to 4. On the other hand, most of the stores that opened before 2011 and that are target of refurbishment under the Project are believed to be using HCFC and the ratio of stores that use HFC will increase every year. It is decided that three-year project schedule is examined here, with the fluorocarbon recovery and destruction scheme regardless of the fluorocarbon type.

Based on the assumption that there will be a total of 1,700 FamilyMart stores in 2017³, 200 stores are estimated to open every year. The number of stores to be refurbished is assumed to be 50 per year⁴.

³ It is assumed based on various media information and interviews.

⁴ It is assumed based on interviews at several stakeholders.

Table 2.7.2 Tentative Project Schedule (T-2)

Time	Contents
FY2014	Proposal of outline of energy-efficiency improvement
FY 2015 or later Year 1	Facility replacement ➤ Refurbishment of 50 stores ➤ 200 new stores
Year 2	Facility replacement ➤ Refurbishment of 50 stores ➤ 200 new stores
Year 3	Facility replacement ➤ Refurbishment of 50 stores ➤ 200 new stores

(2) Main technologies to be introduced

Since the application of the fluorocarbon recovery and destruction scheme is envisioned, energy saving by replacement of refrigeration showcases and air conditioning systems (or new introduction for new stores) is studied. Efforts are also made to save energy of lightings.

Since approximately 60% of current air conditioning systems are non-inverter type, they are assumed to be replaced with inverter control-packaged systems. Replacement of the refrigeration showcases with inverter showcases is also considered. The lighting apparatus is assumed to be Hf fluorescent or LED lamps.

Economic performance of this replacement was studied later separately.

(3) Project cost

The cost of energy saving and conventional air conditioning systems, refrigeration showcases, and lighting are studied here.

The introduction cost of energy saving equipment is approximately 1 million baht (approximately 3.3 million yen) per store and this can be regarded as the project cost. However, because air conditioning systems, refrigeration showcases, and lighting are essential equipment to be introduced when convenience stores are newly opened or refurbished even it is not for improving energy efficiency, the project cost can also be the difference with the cost of introduction of conventional equipment (823,000 baht or approximately 2.72 million yen per store) (additional cost). The project cost herein is estimated based on the latter idea.

The additional cost for the introduction of energy saving equipment is 186,400 baht (approximately 615,000 yen) per convenience store. Since there are 250 target stores annually under

the abovementioned introduction schedule, the annual project cost is estimated to be 47 million baht (154 million yen).

(4) Tentative project implementation structure

The tentative project implementation structure is shown in the figure below. Entities and their roles in the figure are currently under coordination and the scheme herein is a proposal.




Figure 2.7.4 Project Implementation Structure (Proposal) (T-2)

7.2.2 CO₂ reduction

(1) CO₂ reduction

The CO₂ reduction per store is estimated based on the following assumption:

<Preconditions of estimation>

- ① Power consumption per store is 100,000kWh per year.
- ② 75% of power consumption is used for air-conditioning, refrigeration and lighting.
- ③ Replacement with energy saving air conditioning systems, refrigeration systems, and lighting equipment results in 35% reduction of power consumption. It is 26% reduction (75% x 35%) for the entire store.
- ④ The CO₂ emission basic unit requirement of grid power is 0.55t-CO₂/MWh. It is obtained based on the assumption that it is slightly improved because the ratio of coal thermal power generation has declined as the ratio of natural gas power generation has increased, although the figure announced by the Thai Government in 2010 was approximately 0.58 t-CO₂/MWh.

With the assumption above, CO₂ emissions are estimated to decrease by 14tCO₂/y (100,000kWh×26%×0.55tCO₂/MWh) per store. If 250 stores introduce the energy saving equipment annually, the reduction amount is estimated to be 3,500tCO₂/y in total. (See below figure.)




Figure 2.7.5 Estimated CO₂ Emissions Reduction in T-2 Project

Cost effectiveness on subsidy is calculated to be 3,700 Yen/tCO₂ (77 million Yen/3,500 tCO₂/6 durable years).




Figure 2.7.6 Cost Effectiveness in T-2 Project

(2) HFC recovery and destruction volume

The HFC recovery and destruction volume of existing stores is also estimated. Approximately 15kg of HFC (R404A) is estimated to be used per store⁵. The amount is converted into 60tCO₂ per store (=15kg×3920 : R404A GWP) among refurbished stores. In other words, 60tCO₂ of GHG reduction is added per store, as the ratio of HFC stores increases in T-2 project.

⁵ According to interview with manufacturers, etc.

8. Examination of MRV Methodologies

8.1 Japanese food manufacturer

The GHGs subject to reduction in the Project includes HFC that is designated under the Kyoto Protocol in addition to CO₂. Thus, evaluation methods of fluorocarbon destruction effects was also studied in addition to the methodology for CO₂ emissions reduction. The study for establishing the calculation method of CO₂ emissions reduction is described herein.

Although the target of the Project is the replacement of refrigeration system of food manufacturers in Thailand, the methodology was examined to make it as general as possible so that the method can be used widely for the replacement of similar industrial refrigeration system.

The JCM methodologies (proposal) described herein was developed as the outcome of the study and its application under the joint crediting mechanism is not officially approved.

(1) Definition of terms

The energy saving method of the Project is the replacement of refrigeration equipment. The emissions reduction is estimated by multiplying the gap of power that is (assumed to be) consumed by the project refrigeration equipment and reference refrigeration equipment by the GHG emission basic unit requirement of grid power. The terms used herein are defined as described in the table below.

Partly because the refrigeration equipment has long service life in general, existing refrigeration equipment may be used continuingly without the JCM project in some cases. Thus, the definition of the reference refrigeration equipment is classified into two—one is when there is an equipment replacement plan without the JCM project and the other is when there is no such plan without the project.

Table 2.8.1 Definitions (T-1)

Term	Definition
Refrigeration equipment	Heat source facility that generates cold air by transferring heat based on the heat pump principle
Project refrigeration equipment	Refrigeration equipment that is introduced in the JCM project
Reference refrigeration equipment	<There is an equipment replacement plan without the JCM project.> Refrigeration equipment that (are believed to) has the biggest market share in the target country at the time of replacement or refrigeration equipment with functions that are average of several major manufacturers that distribute their products in the target country <There is no equipment replacement plan without the JCM project.>

	Existing refrigeration equipment that becomes the target of the replacement in the Project
Coefficient of performance	Refrigerating capacity [kW] / main motor input power [kW]

(2) Eligibility criteria

Although the Project targets a specific plant (food manufacturer) as described above, refrigeration equipment are widely used at other industrial plants and their replacement, which includes recovery and destruction of fluorocarbons as refrigerant, can happen in other sectors. Thus, the criterias were examined without limiting the use and characteristics of the target facility so they can be applied to other facilities that include plants of other sectors, hospitals, and commercial facilities.

Possible eligibility criteria include the following:

Criteria 1: Refrigeration equipment that consumes electricity only and generates cold air

Criteria 2: It is the replacement of existing facility.

Criteria 3: Electricity supplied to the reference and project refrigeration equipment is grid power from a power company in the country.

Inclusion of another requirement that the fluorocarbons contained as the refrigerant be the substance designated under the Kyoto Protocol was also considered as a eligibility criteria. However, as it is pointed out in the Montreal Protocol, the proper recovery and destruction is meaningful even they are not substances designated by the Kyoto Protocol (HCFC, etc.). Thus, it was decided that it is not included as a requirement herein and that is treated as CO-Benefit.

(3) Reduction volume calculation method (proposal)

The calculation method at each facility is decided based on the flow chart below.




Figure 2.8.1 Flow of Calculation Method Selection (T-1)

The efficiency of reference and project refrigeration equipment used in calculation methods 1 to 4 is provided in the table below.

Table 2.8.2 Efficiency Assumption Method of Calculation Methods 1 to 4

Estimation Method	Efficiency of Reference Freezer	Efficiency of Project Freezer
1	Use actual values.	Use actual values.
2	Use actual values.	Use catalogue values.
3	Use catalogue values.	Use actual values.
4	Use catalogue values.	Use catalogue values.

The reference emissions (RE) and project emissions (PE) in Year “y” are estimated based on the following formula:

$$RE = Q/R\eta / (3.6 \times 10^{-3}) \times EF$$

RE: reference emissions [t-CO₂/y]

Q: cold air volume generated in Year y [GJ/y]

Rη: efficiency of reference refrigeration equipment

EF: emission factor of grid power in the target country in Year y [t-CO₂/kWh]

$$PE = Q/R\eta / (3.6 \times 10^{-3}) \times EF$$

RE: project emissions [t-CO₂/y]

Q: cold air volume generated in Year y [GJ/y]

P_η: efficiency of project freezer

EF: emission factor of grid power in the target country in Year y [t-CO₂/kWh]

The destruction effects of fluorocarbons designated under the Kyoto Protocol, contained as the refrigerant of the project refrigeration equipment, are not included herein. The evaluation methods is examined later separately.

8.2 Convenience store

The target GHG reduction in the project include the fluorocarbon (HFC) that is designated as GHG under the Kyoto Protocol in addition to CO₂. Thus, the evaluation methods of fluorocarbon destruction effects were also examined in addition to the methodologies for CO₂ emissions reduction. The study for establishing the calculation method of CO₂ emissions reduction is described herein. Since MRV methodologies for CO₂ for the energy-saving projects of refrigeration showcases, air-conditioning systems and lighting of convenience stores in Thailand have been developed to some degree through past survey and research, the concept is employed and partial changes are made.

The JCM methodologies (proposal) described herein were developed as the outcome of the study and its application under the joint crediting mechanism is not officially approved.

(1) Idea of the methodologies

The energy-efficiency improvement measures for convenience stores in the Project are the replacement of refrigeration showcases, air-conditioning systems and lighting and their introduction to new stores. Possible methods of calculating the reduction amount are to accumulate the effects of each equipment (build-up method) and to estimate it based on the total power consumption of the store (total index method). As convenience stores are standardized, it is more realistic to use a method of utilizing the characteristics of them.

An overview of the characteristics and advantages and disadvantages of the methods are described in the table below. Although the disadvantage of the total index method is lowering of accuracy when the facility specifications vary, its impact is likely to be small as convenience stores are standardized and thus it is more realistic to use the method.

Table 2.8.3 Overview of Build-Up Method and Total Index Method

Method	Overview	Advantage	Disadvantage
Estimation by accumulating equipment (build-up method)	Estimate the reduction volume from measured power consumption of target equipment of each facility.	Can be estimated accurately.	High cost; complicated; and consume additional energy with monitoring equipment
Estimation from total store power consumption (total index method)	Estimate the reduction from the gap of power consumption of baseline facility and project facility.	Simple, low cost	Accuracy deteriorates when store specifications differ.

Source: Compiled based on the Feasibility Study on Green Convenience Stores with High- Efficiency Equipment in Thailand and Vietnam FY2012, NEDO

(2) Eligibility criteria

The criterias below need to be met to use the total index method. One criteria of the target of the Project is that they need to introduce high-efficiency air-conditioning system and refrigeration showcases among the three equipment (air-conditioning system, refrigeration showcases and lighting). It is because the purpose of the Project includes recovery and destruction of refrigerant fluorocarbons and the two equipment use the refrigerant. The lighting is not regarded as a criteria because it is not in the scheme and the introduction of at least the two equipment, if not all of the three, will enable sufficiently accurate calculation based on past survey and research.

Table 2.8.4 Criteria for Application of Total Index Method

Category	Requirement for Application
Definition of “store”	Small store whose style and operation are standardized and whose total power consumption can be obtained from the bill of the power company
Target of the Project	At least air-conditioning system and refrigeration showcase are high-efficiency equipment among those two and lighting. (Two or more is sufficient enough to estimate satisfactory level of accuracy because the ratio of power consumption of the three equipment to the total consumption is stable among stores.)
Environmental condition	Illuminance and room temperature serve as benchmarks and they do not fluctuate more than 10% from before the refurbishment if it is a refurbished store, and from the manual of the operator for new stores (set to be 10% in reference to the existing study results (source). Validity needs to be examined by gathering data.)

Implementation condition	As the number of samples, there are more than 100 stores in one country and one climate zone. (The number of samples of small-scale CDM methodology AMS- II-AE is also more than 100.)
--------------------------	--

Source: Compiled based on the Feasibility Study on Green Convenience Stores with High- Efficiency Equipment in Thailand and Vietnam FY2012, NEDO

(3) Calculation method

The calculation methods are selected based on the three conditions: existing or new store (existing store $\Rightarrow$ calculation method 1); if it is a new store, model formula can be created (calculation method 2) or default value is used (calculation method 3). The calculation method of reference power consumption differs among the calculation methods 1 to 3 and their overview is shown in Table 2.8.5.

Table 2.8.5 Overview of Reference Annual Power Consumption Calculation Methods 1 to 3

Calculation Method	Calculation Method of Reference Annual Power Consumption
1	Actual data of store before refurbishment (minimum value of annual power consumption for 3 years before refurbishment)
2	Calculation using model formula <Model formula> Reference power consumption = $a \times \text{store floor area} + b \times \text{number of customers}$ + $c \times \text{number of lighting apparatus}$ + $d \times \text{number of air-conditioning system}$ + $e \times \text{number of showcase} + \dots$
3	Default value (specific consumption) $\times$ store floor area Default value (specific consumption): annual power consumption per area Actual figures of Japan Franchise Association are used.

Source: Compiled based on the Feasibility Study on Green Convenience Stores with High- Efficiency Equipment in Thailand and Vietnam FY2012, NEDO

The estimation formula of reference emissions (RE) and project emissions (PE) in Year “y” of calculation methods 1 to 3 is shown below.

<Estimation method 1>

$$REy = \sum RECi,y \times EFCO_{2,elec}$$

Rey: reference CO₂ emissions in Year y [t-CO₂/y]

REC i,y: annual power consumption of target store i before refurbishment [MWh/y]

EFCO_{2,elec}: CO₂ emissions factor of grid power [t-CO₂/MWh]

$$PEy = \sum PECi,y \times EFCO_{2,elec}$$

PEy: project CO₂ emissions in Year y [t-CO₂/y]

PEC i,y: annual power consumption of project store i in Year y [MWh/y]

※Project store herein refers to store after refurbishment.

EFCO_{2,elec}: CO₂ emissions factor of grid power [t-CO₂/MWh]

<Estimation method 2>

$$REy = RECy \times EFCO_{2,elec}$$

Rey: Reference CO₂ emissions in Year y [t-CO₂/y]

RECy: Reference annual power consumption [MWh/y]

EFCO_{2,elec}: CO₂ emissions factor of grid power [t-CO₂/MWh]

RECy is shown in the multiple regression model⁶ with power consumption as the objective variable and the parameter of store floor area as the explanatory variable.

$$RECy = \sum i (ECi,m,y - SEy)$$

$$ECi,m,y = a \times SAi,y + b \times NCi,y + c \times ODi,y + \sum j (dj \times Xi,j,y) + e$$

RECy: reference annual power consumption [MWh/y]

ECi,m,y: power consumption of quasi reference store in Year y, obtained with the multiple regression model based on conditions of project store i [MWh/y]

SEy: standard error of average of reference annual power consumption with 90% reliability

SAi,y: store floor area of project store i in Year y [m²]

NCi,y: number of annual customers of project store i in Year y [person/y]

ODi,y: date of opening or refurbishment of project store i in Year y [yyyy/mm/dd]

Xi,j,y: Value of other explanatory variable of project store i in Year y

a,b,c,dj,e: invariable of each explanatory variable of multiple regression model

⁶ Feasibility Study on Green Convenience Stores with High- Efficiency Equipment in Thailand and Vietnam FY2012, NEDO

$$PE_y = PEC_y \times EFCO_{2,elec}$$

PE_y: project CO₂ emissions in Year y [tCO₂/y]

PEC_y: annual total power consumption of target project store [MWh/y]

EFCO_{2,elec}: CO₂ emissions factor of grid power [tCO₂/MWh]

$$PEC_y = \sum (PEC_{i,y})$$

PEC_{i,y}: annual power consumption of project store i in Year y [MWh/y]

<Estimation method 3>

$$RE_y = RE_y \times EFCO_{2,elec}$$

RE_y: reference CO₂ emissions in Year y [t-CO₂/y]

RE_y: Reference annual power consumption [MWh/y]

EFCO_{2,elec}: CO₂ emissions factor of grid power [t-CO₂/MWh]

RE_y is obtained with the default value of the annual power consumption per area. One method of setting the default value is to use the annual power consumption per area of convenience stores in Japan, which is estimated to be 1103.76kWh/m²·y base on the actual figure of 0.126kWh/m²·h in FY2009, which is released by Japan Franchise Association. The updated value shall be used when the association releases new figures.

$$RE_y = \sum (ECD \times SAI_{i,y})$$

ECD: annual power consumption per area (default value) [MWh/m²·y]

SAI_{i,y}: store floor area of project store i in Year y [m²]

$$PE_y = PEC_y \times EFCO_{2,elec}$$

PE_y: project CO₂ emissions in Year y [tCO₂/y]

PEC_y: annual power consumption of all target project stores [MWh/y]

EFCO_{2,elec}: CO₂ emissions factor of grid power [tCO₂/MWh]

$$PEC_y = \sum (PEC_{i,y})$$

PEC_{i,y}: annual power consumption of project store i in Year y [MWh/y]

8.3 Evaluation methods of fluorocarbon destruction effects

The following needs to be clarified to evaluate the effects of fluorocarbon destruction in the Project as GHG emissions reduction:

- ① Agreement to evaluate the effects of fluorocarbon reduction (HFC in particular) by the joint committee (Thai T-VER does not include HFC in the target gases.)
- ② Guarantee of traceability in each process of recovery and destruction

As for ①, GtoG negotiation results are waited for and as for ②, it needs to be examined continuingly, including that of how to guarantee the traceability, in Thailand.

With the assumption that the above two issues are clarified, the methods to evaluate the effects of fluorocarbon destruction were studied. Further close study is needed to include the effects of fluorocarbon destruction as the GHG emissions reduction of the Project.

8.3.1 Existing methodologies

CDM small-scale methodologies that include AMS-III.X. (Energy Efficiency and HFC-134a Recovery in Residential Refrigerators), AMS-III.AB.(Avoidance of HFC emissions in Standalone Commercial Refrigeration Cabinets) have been developed and approved as existing methodologies to estimate GHG reduction effects through recovery and destruction of refrigerant fluorocarbons (alternative fluorocarbons) and insulation fluorocarbons or replacement with refrigerant of low global warming potential. US Climate Action Reserve that is a carbon credit certification program provides the protocol to evaluate the effect of fluorocarbon destruction.

In reference to the idea of existing methodologies, the evaluation methods of effects of fluorocarbon recovery and destruction are likely to be implemented based on the following policies:

- GHGs that are emitted at destruction process are taken into consideration. Energy consumption of reclamation is assumed to be low.
- New demand for alternative refrigerant is taken into consideration when the refrigerant which is otherwise reclaimed or traded in market is destroyed.

Table 2.8.6 Examination of Evaluation Methods of Effects of Fluorocarbon Recovery and Destruction

Item	Montreal Protocol		Kyoto Protocol
	CFC	HCFC	HFC
Situation in target country	Completely abolished by 2010.	Gradually reduced from 2015 and completely abolished by 2040.	Conversion from ODS is in progress and there is no reduction target in the consumption side.
International policy	Production and consumption are completely abolished.	Reclamation and other measures are needed to reduce production.	There is no policy on the production side. Recovery is needed to prevent emissions.
Application conditions	Project contents are not mandatory under laws or regulations.	Recovery is not a legal requirement and it has not spread.	Recovery of HFC is not a legal requirement and it has not spread.
Reclaimable refrigerant ※by formal reclamation operator	Amount of destruction is evaluated. (consideration) • Emissions by destruction	Amount of reclamation is evaluated.	Amount of reclamation is evaluated.
Refrigerant that cannot be reclaimed	Amount of destruction is evaluated. (consideration) • Emissions by destruction	Amount of destruction is evaluated. (consideration) • Emissions by destruction	Amount of destruction is evaluated. (consideration) • Emissions by destruction
Destruction of refrigerant that is otherwise reclaimed and traded in the market	Amount of destruction is evaluated. (consideration) • Emissions by destruction	Amount of destruction is evaluated. (consideration) • Emissions by destruction • Amount of alternative refrigerant	Amount of destruction is evaluated. (consideration) • Emissions by destruction • Amount of alternative refrigerant

Chapter 3 Results of the Study in Malaysia


1. Overview of the Target Country

1.1 Measures against climate change

1.1.1 Greenhouse gas (GHG) emissions

(1) Trend of CO₂ emissions

The trend of CO₂ emissions in Malaysia are shown in Figure 3.1.1. It illustrates the increase in the emissions in line with economic growth. By sector, CO₂ emissions from electricity and heat-derived sector accounts for nearly 50 percent of the total emissions. Equipment that uses fluorocarbons (chiller and air conditioning system) that are the target of the survey consumes much electricity and curbing their power consumption is critical as it contributes to CO₂ emissions reduction in Malaysia.



Source: Compiled based on IEA (International Energy Agency) data データより作成


Figure 3.1.1 Trend of CO₂ Emissions in Malaysia

(2) Trend by power source

The electricity sector accounts for nearly 50% of CO₂ emissions in Malaysia and the trend of power generation by power source (fuel) is summarized in Data source: IEA

Figure 3.1.2. Although natural gas accounted for approximately 70% of power generation until around 2000, the ratio of coal has increased sharply recently.

The grid power CO₂ emission factor has been on the rise recently in the country in line with the increase in the ratio of coal-fired power and the value on the Malay Peninsula exceeded 0.7tCO₂/MWh in 2012.



Data source: IEA

Figure 3.1.2 Trend of Electric Power Generation by Power Source in Malaysia

1.1.2 Low-carbon policies

(1) Overview of environmental policies

The Environmental Quality Act 1974 was enacted in 1974 in Malaysia and the Ministry of Science, Technology and Environment released the national environmental policy (NPE) that incorporates the idea of aiming at sustainable development in all development plans in 2002. Vision 2020 that aims to be a member of developed nations in economic, political, social, mental, psychological and cultural aspects and the Malaysia Plan that sets macroeconomic growth target of every five years serve as guidelines for socioeconomic development at the national level. The current 10th plan (2011 to 2015) contains a plan to launch a GHG emissions reduction program in the five domains, promotion of investment in renewable energies, promotion of energy saving by improving energy use efficiency, improvement of solid waste management, forest conservation, and reduction of pollution emissions towards improvement of air pollution.

(2) Low-carbon policies

Prime Minister Najib Razak established the Ministry of Energy, Green Technology and Water Malaysia after he assumed the post in April 2009 and he launched the National Green Technology Policy in July in the same year as electricity and energy policies. The policy contains five goals: economic growth accompanied by reduction of energy consumption rate, growth of green technology industry and its contribution to national economy, technological improvement for green technology development and reform and enhancement of global competitiveness, securing sustainable development and environmental conservation for future generations, and raising

awareness of green technology and promotion of its utilization. The government launched the Green Technology Financing Scheme in January 2010 and provides low-interest loans of up to 50 million Ringgit (up to 15 years) for companies that supply green technology and up to 10 million Ringgit (up to 10 years) for companies that use it. Green technology in the National Green Technology Policy is supposed to meet the following criteria:

- 1) Minimize environmental deterioration.
- 2) Control GHG emissions to zero or a low level.
- 3) Promise safe use and healthy and higher-quality environment for all styles of living.
- 4) Save use of energy and natural resources.
- 5) Promote use of renewable energies.

(3) Renewable energy policies

The Ministry of Energy, Green Technology and Water formulated a program for small-scale renewable energy in 2001, which enabled power plants of 10MW or less capacity that use renewable energies as resources to sell electricity to the electricity grid. The country also introduced the feed in tariff in April 2010 as an incentive policy for renewable energies and it required Tenaga Nasional Berhad (TNB), Sabah Electricity Sdn Bhd (SESB) and other companies that are authorized to transmit and distribute electricity to purchase electricity generated with biomass, biogas, small-scale water power and solar power by individuals or companies that are certified by the Sustainable Energy Development Authority (EDA) at a fixed price.


The government has set a goal of raising the ratio of renewable energies that was below 1% of all power generation in 2009 to 5.5% by 2015, 11% by 2020 and 17% by 2030 in the National Renewable Energy Policy and Action Plan. The government, led by the Ministry of Energy, Green Technology and Water, plans to establish a renewable energy fund to be operated by a sustainable energy development agency for implementing the plan.

1.2 Fluorocarbon measures

1.2.1 Flow of fluorocarbons used as refrigerant

The flow of fluorocarbons that are used as refrigerant, which was learned from the results of Year 1 project and project of this fiscal year, is shown below. In Malaysia, refrigerant itself is not designated as a hazardous substance, although its intentional discharge into the air is prohibited. It is assumed that the used refrigerant generated in the manufacturing process is commissioned to be disposed of or reclaimed at external destruction facility under the responsibility of manufacturers (particularly Japanese manufacturers). On the other hand, most of the refrigerant inequipment during its use is managed by distributors and maintenance operators or sectors. Although some maintenance

operators reclaim the refrigerant they collect, most of it, including refrigerant in end-of-life equipment, is believed to go into an informal flow.



Source: Compiled based on interview results

Figure 3.1.3 Flow of Fluorocarbons Used as Refrigerant

1.2.2 Relevant regulations

As is the case in Thailand, there are two types of regulatory programs: one is to regulate fluorocarbons directly and the other is to regulate end-of-life equipment. Although fluorocarbons are not designated as hazardous substances in Malaysia, their discharge into the air is prohibited by the Environmental Quality (Refrigerant Management) Regulations 1999 (which is regulations on imports, consumption, use and recovery). Currently, the target of the regulation is limited to CFC only and it mainly regulates emissions by the service sector. In the revision that aims at its implementation in July 2015, provision on HCFC and provision on destruction (disposal of used fluorocarbons at certified facilities) are planned to be added. As for approval of destruction facilities, requirements related to destruction in the Montreal Protocol Handbook are supposed to be referred to.

In Malaysia, end-of-life equipment (E-waste) is designated as schedule waste (SW110) under the Environmental Quality (Scheduled Wastes) Regulations, 2005, and it is required to be disposed of by

business operators with SW110 license. Industrial E-waste that is the target of the Project needs to be delivered to licensed business operators. As for equipment for household use, E-waste itself is under the supervision of the DOE. However, the MHLG is responsible for collection and disposal of waste from households and the DOE and the MHLG are examining the collection method of E-waste.

2. Fact-Finding Survey of Energy Saving Equipment Use

2.1 Overview of the survey

We carried out fact-finding survey of energy saving equipment use of commercial and public facilities and plants around Johor Bahru as the study in Malaysia. We conducted questionnaire survey and then walk-through survey to understand the facility conditions as we did in Thailand.




Figure 3.2.1 Flow of Fact-Finding Survey (Malaysia)

2.2 Questionnaire survey

We conducted questionnaire survey with commercial or institutional buildings (hotel, hospital, shopping mall) as well as some industrial facilities in Johor Bahru on their use of refrigeration equipment and we obtained responses from 13 facilities. We compared the results about the following indicators and selected potential facilities for a JCM project.

<Selection criteria>

- ◆ Refrigeration equipment were installed many years ago. (There will be much room for energy saving.)
- ◆ Relatively big scale.
- ◆ Have interest in replacement.
- ◆ Have understanding of and interest in the purpose of the project.

We selected a hospital, a shopping mall, and a university as potential facilities based on the above selection criteria.

2.3 Fact-finding survey

2.3.1 National hospital (M-1)

(1) Interview survey results

- There are five chillers, 114 AHU units, and 100 FCU units in the main building.
- Maintenance work of the chillers is performed monthly internally.
- The chillers are operated in a cycle of two weeks by operating two chillers continuously for two weeks. One chiller is out of order (Unit 5) and one is under repairment (Unit 1).
- Although a BAS (Building Automation System) is installed, it is not used as it is not capable of controlling the chiller system.
- The primary chiller pump has no inverter and the secondary pump is inverter control.




Figure 3.2.2 Fluctuations of Monthly Power Consumption (2011 to 2014)



	
Cooling water pump	Pump inverter
	
Refrigerant for stock (R-134a)	AHU

2.3.2 Commercial facility (M-2)

(1) Interview survey results

- The chiller for the air conditioning system of the building has not been replaced since its completion in 1988.
- One chiller is usually in operation for the air conditioning system. Installation of four chillers seems excessive. It is because residence and hotel were originally planned to be built together but only the residence was built partially in reality.
- The chiller for the air conditioning system operates in a cycle of three weeks from 11 a.m. to 10p.m. daily. Maintenance work is performed monthly.
- As the secondary cold water pumps, there is one 45kW unit (ECON SAVE system) and three 110kW units (SPB systems 1 to 3) and one unit is in operation continuingly in each system. No primary cold water pump is introduced. One 78kW cooling water pump is in operation continuingly.

	
Model of facility exterior	Chiller
	
Cold water pump	Cooling water pump

2.3.3 University (M-3)

(1) Interview survey results

- Sultan Iskandar Hall (commonly called DSI building) has a capacity for 500 persons and one chiller was in operation on the day of interview (100% load factor).
- One chiller of C16 building was in operation on the day (57% load factor). The chiller of the building operates five days a week from 7:30 a.m. to 4:30 p.m. daily. The chiller was replaced from CFC-11 to HCFC-123 and the cooling capacity reduced from 300TR to 240TR. 5 units of 50TR module chillers are planned to be installed newly.

	
Module chiller	Chiller (DSI building)
	
Cold water pump (DSI building)	Chiller (C16 building)

3. Study on Logistics and Collection of Fluorocarbons

3.1 Current situation of recovery of fluorocarbons

As for collection and disposal of end-of-life equipment, business operators with an SW110 license authorized to dispose of E-waste are divided into two categories, full-license and partial-license holders. Full-license holders crush and sort E-waste and recover metals. Partial-license holders only crush and sort E-waste and are required to outsource for further treatment to full-license holders.

As for recovery of fluorocarbons, the recovery service operators are required to receive training on handling of fluorocarbons and obtain a license under the Environmental Quality (Refrigerant Management) Regulations 1999. The Authorized Training Center (ATC) of Malaysia provides legally required CFC training and it plans to launch HCFC training. The ATC distributes recycling machines to remove water and other impurities in end-of-life refrigerant to the service sector. Since the training is provided for the service sector and thus no disposal stage is assumed, few SW110 operators are likely to have received it.

As for the logistics, partial- and full-SW110 license holders described above are allowed to transport E-waste and they are also authorized to transport fluorocarbon-containing equipment. They exist in certain numbers in each state and they have their own collection system and thus it will be possible to use them in the Project.

3.2 Current situation of destruction of fluorocarbons

3.2.1 Existing facility

Fluorocarbon disposal facilities that are in operation in Malaysia are Texcarrier (reclamation) and Kualiti Alam (destruction).

① Texcarrier

Main business of the company is to import fluorocarbons and sell them to distributors in the country. It also receives used fluorocarbons from refrigeration system service operators, removes impurities, reclaims them and sells as the reclaimed products. It began recycling and reclamation of refrigerant about eight years ago in Malaysia.

It can receive used fluorocarbons if proper mixtures or impurities are less than 0.5% and it instructs proper recovery methods to service operators. As of 2014, 60% to 70% of the amount they received was R-22. If they cannot be reclaimed and thus they need to be destroyed, it outsources the disposal to later described Kualiti Alam when it accumulates a certain amount. The amount of used fluorocarbons it receives from service operators is small compared with the amount of virgin fluorocarbons it handles. The amount of the used fluorocarbons received generally depends on the price of the virgin fluorocarbons.

② Kualiti Alam

Kualiti Alam, established in 1991, is the only hazardous waste incineration facility in Malaysia. It is equipped with rotary kilns and exhaust gas is treated with the dry scrubber, bag filter, and wet scrubber. Two kilns are in operation and one of them is for hazardous waste treatment with a daily capacity of 120 tons. Solids stay in the kiln for approximately 40 minutes. The other kiln is for medical waste with a daily capacity of 30 tons to 40 tons. The bottom of the landfill is protected with the clay layer and impermeable liner and leachate is collected.

In response to the request from the DOE, it began destruction of fluorocarbons in 2009. It destroys about 10 tons of fluorocarbons annually. It uses a rotary kiln with a daily capacity of 120 tons for fluorocarbon destruction. The combustion temperature is 1,000 to 1,100°C and the gas stays two to three seconds in the kiln. It does not monitor or calculate the destruction capacity specifically of fluorocarbons. However, it controls the input volume under 5psi and can input approximately 600kg to 700kg of fluorocarbons in 24 hours. The disposal fee differs in accordance with the amount of fluorocarbons, although it is 12 MYR/kg (approximately 400 yen/kg) for large-volume fluorocarbon emitters (1 ton level). Kualiti Alam destroys R-22 (approximately 73%), R-410a (approximately 18%) and others (below 2% each). Most of the fluorocarbons it destroys is the refrigerant discharged by air conditioning system manufacturers.

3.2.2 Other options of fluorocarbon destruction

① Cement company

Lafarge and YTL that are cement companies show their interest in the destruction of fluorocarbons and they visited Holcim (performs the destruction) in Indonesia together with the DOE. Both companies are considering performing the destruction as CSR activities. Although they have no technological problem, they have concerns on the introduction of a destruction permit program and that they will not be able to collect a sufficient amount of fluorocarbons that will match the facility investment. Lafarge assumes that it will be able to establish destruction facility without thinking about the supply volume if they can receive subsidies for the investment from international organizations, etc. YTL estimated the destruction capacity and believes that it is capable of destruction of 385 tons annually. Although the destruction cost differs case by case, both companies believe that it is lower than that of Kualiti Alam. They are required to obtain DOE permit for destruction and take environmental impact assessment (EIA) procedures to perform the destruction.

② EU fluorocarbon destruction project in Southeast Asia

The UNEP works in collaboration with various countries under the Montreal Protocol and we interviewed officials in charge of Southeast Asia. They introduced a fluorocarbons destruction project in the region. It is a project in which EU provides funds and works in collaboration with

other international organizations to promote fluorocarbon destruction in the region. However, they face a problem of fluorocarbon recovery for the destruction and they also showed interest in the Project. The Montreal Protocol emphasizes phase-out of fluorocarbon production and consumption and they recognize the problem of used fluorocarbon disposal. However, they are capable of implementing limited measures due to budgetary restrictions.

Efficient recovery and destruction of fluorocarbons can be achieved in the Project in collaboration with other destruction projects including the one introduced above.

4. Study of Collection system

As is in the case of Thailand, sustainability of the recovery system is important for the collection system. Since the revision of the fluorocarbon management regulation in July 2015 in Malaysia provides fluorocarbon disposal at certified facilities, slight progress is expected to be made. However, it is likely to take time to develop a sustainable recovery system. Particularly, the cost-bearing issue will remain to be a big challenge. Packaging with the replacement with energy saving equipment in the Project will serve as the incentive for fluorocarbon recovery and destruction.

Collaboration in each step of the collection system described in the below table is options of the Project.

Table 3.4.1 Options of Collection System in Malaysia

Step of Collection System	Available Option in the Project
Collection of end-of-life equipment from the site	Use collection network of SW110-licensed business operator.
Recovery of used fluorocarbons	Receive training on fluorocarbon handling and utilize qualified service providers or SW110-licensed operators.
Dismantle of end-of-life equipment	Can be performed by SW110-licensed operator. ※Proper operators need to be selected depending on the target equipment.
Reclamation of fluorocarbons	Texcarrier can reclaim them if the impurities content of recovered refrigerant is below 0.5%.
Destruction of fluorocarbons	Hazardous waste incineration facility can be used. When a cement company introduces fluorocarbon destruction facility, collaboration with the company can be an option. Traceability, guarantee of proper disposal, and destruction cost, etc, will be taken into consideration to decide the destruction service operator.

5. Examination of Implementation Structure and Finance Scheme

5.1 National hospital (M-1)

5.1.1 Project overview

(1) Tentative schedule

Based on the fact-finding survey results, chillers (2 of 5 700RT units) for the air conditioning system are the target facility of the JCM project. Since two units are in operation continuously (2 weeks per unit), they can be replaced individually. Thus, we can examine a replacement plan (1 or 2 units per year) in accordance with the budget allocation. The tentative schedule is based on the assumption of replacement of one unit per year.

Table 3.5.1 Tentative Project Schedule (M-1)

Time	Contents
FY2014	Proposal of outline of energy-efficiency improvement
FY 2015 or later Year 1	PS implementation ➤ Adjustment of details of equipment specifications ➤ Discussions of implementation structure
Year 2	Facility replacement ➤ Replacement of 1st chiller for air conditioning system
Year 3	Monitoring ➤ Replacement of 2nd chiller for air conditioning system ➤ Monitoring of energy consumption, etc., of 1st unit
Year 4	Monitoring of energy consumption, etc.

(2) Main technologies to be introduced and project cost


【Efficiency improvement of heat source equipment】

A refrigeration equipment manufacturer estimates that replacement of a refrigeration equipment that was produced 10 years ago with the latest high-efficiency equipment will lead to 36% electricity cost reduction (estimation in Japan) and 24% reduction of CO₂ emissions.

Compare to our previous model, the operation expense is 36% lower! And the CO₂ emission is 24% lower



If the current type of HCFC-123 refrigerant is replaced with HFC-134a or HFC-245fa, ODP will become zero although GWP increases. As for the GWP increase, global warming risk can be suppressed through proper recovery and destruction of refrigerant at replacement and maintenance.



As for the project cost, the additional cost for the introduction of energy saving equipment is estimated to be 38 million yen per refrigeration equipment according to the interview result with manufacturers, etc. Since one unit is to be replaced per year in the project, the annual project cost and total project cost are estimated to be 38 million yen and 76 million yen, respectively.

(3) Tentative implementation structure

The tentative project implementation structure is shown in the figure below. Entities and their roles in the figure are currently under coordination and the scheme herein is a proposal.




Figure 3.5.1 Project Implementation Structure (proposal) (M-1)

5.1.2 CO₂ reduction

The CO₂ reduction after the replacement with energy saving equipment based on the technology introduced in 5.1.1 is estimated as below.

- **Contents of Replacement**

700TR × 2 unit to be replaced

- **Annual Reduction of Power Consumption**


Reference annual CO₂ reduction: 340t-CO₂/Year (2 units)

- **GHG Reduction by HFC Destruction**

Approx. 400kg × 1unit × 1300=520t-CO₂/unit

- **Approximate Investment Cost**

76,000,000 Yen (2 units)



5.2 Commercial facility (M-2)

5.2.1 Project overview

(1) Tentative schedule

Based on the fact-finding survey results, chillers (2 of 4 720RT units) for the air conditioning system are the target facility of the JCM project. Since two units are in operation continuously (3 weeks per unit), they can be replaced individually. Thus, we can examine a replacement plan (1 or 2 units per year) in accordance with the budget allocation. The tentative schedule is based on the assumption of replacement of one unit per year.

Table 3.5.2 Tentative Project Schedule (M-2)

Time	Contents
FY2014	Proposal of outline of energy-efficiency improvement
FY 2015 or later Year 1	PS implementation ➤ Adjustment of details of equipment specifications ➤ Discussions of implementation structure
Year 2	Facility replacement (Unit 1) ➤ Replacement of 1st chiller for air conditioning system
Year 3	Facility replacement (Unit 2) ➤ Replacement of 2nd chiller for air conditioning system ➤ Monitoring of energy consumption of 1st unit
Year 4	Monitoring of energy consumption, etc.

(2) Main technologies to be introduced and project cost

Main technologies to be introduced are same as those described in M-1 project. As for the project cost, however, the additional cost for the introduction of energy saving equipment to the facility is estimated to be 40 million yen per refrigeration equipment based on the interview results with manufacturers. As one unit is to be replaced per year in the Project, the annual project cost and total project cost are estimated to be 40 million yen and 80 million yen, respectively.

(3) Tentative implementation structure

The tentative project implementation structure is shown in the figure below. Entities and their roles in the figure are currently under coordination and the scheme herein is a proposal.




Figure 3.5.2 Project Implementation Structure (proposal) (M-2)

5.2.2 CO₂ reduction

The CO₂ reduction after the replacement with energy saving equipment based on the technology introduced in 5.2.1 is estimated as below.

• Contents of Replacement

720TR × 2 unit to be replaced

• Annual Reduction of Power Consumption


Reference annual CO₂ reduction: 280t-CO₂/Year (2 units)

• GHG Reduction by HFC Destruction

Approx. 900kg × 1unit × 1300=1,170t-CO₂/unit

• Approximate Investment Cost

80,000,000 Yen (2 units)



5.3 University (M-3)

5.3.1 Project overview

(1) Tentative schedule

Based on the fact-finding survey results, the following equipment is the target equipment of the JCM project:

- 2 units of 300TR chillers for air conditioning system for C16 building
- 2 units of 250TR chillers for air conditioning system for DSI building

Since one unit is in operation continuously in both buildings, they can be replaced individually. Thus, we can examine a replacement plan (1 or 2 units per year) in accordance with the budget allocation. The tentative schedule is based on the assumption of replacement of one unit per year.

Table 3.5.3 Tentative Project Schedule (M-3)

Time	Contents
FY2014	Proposal of outline of energy-efficiency improvement
FY 2015 or later Year 1	PS implementation ➤ Adjustment of details of equipment specifications ➤ Discussions of implementation structure
Year 2	Facility replacement (Unit 1) ➤ Replacement of 1st chiller for air conditioning system of C16 building ➤ Replacement of 1st chiller for air conditioning system of DSI building
Year 3	Facility replacement (Unit 2) ➤ Replacement of 2nd chiller for air conditioning system of C16 building ➤ Replacement of 1st chiller for air conditioning system of DSI building ➤ Monitoring of 1st unit of both buildings
Year 4	Monitoring of energy consumption, etc.

(2) Main technologies to be introduced and project cost

Main technologies to be introduced are same as those described in M-1 project. As for the project cost, however, the additional cost for the introduction of energy saving equipment to the facility is estimated to be 98 million yen for four refrigeration equipment based on the interview results with

manufacturers. Since one unit is to be replaced per building per year in the project, the annual project cost for the replacement of two units is estimated to be 49 million yen.

(3) Tentative implementation structure

The tentative project implementation structure is shown in the figure below. Entities and their roles in the figure are currently under coordination and the scheme herein is a proposal.




Figure 3.5.3 Project Implementation Structure (Proposal) (M-3)

5.3.2 CO₂ reduction

The CO₂ reduction after the replacement with energy saving equipment based on the technology introduced in 5.3.1 is estimated as below.

• **Contents of Replacement**


250TR × 2 units and 300TR × 2 units to be replaced

• **Annual Reduction of Power Consumption**

Reference annual CO₂ reduction: 326t-CO₂/Year (4 units)

• **Approximate Investment Cost**

98,000,000 Yen (4 units)



6. Examination of MRV Methodologies

6.1 Examination of MRV Methodologies

The GHGs subject to reduction in the project includes HFC that is designated under the Kyoto Protocol in addition to CO₂. Thus, evaluation methods of fluorocarbon destruction effects was also studied in addition to the methodologies for CO₂ emissions reduction. The study for establishing the calculation method of CO₂ emissions reduction is described herein.

Although the target of the Project is the replacement of chillers for air conditioning systems of a hospital, a shopping mall and a research and educational institute in Malaysia, the methodology was examined to make it as general as possible so that the method can be used widely for the replacement of similar chillers for air conditioning systems used at similar business-use buildings.

The JCM methodologies (proposal) described herein was developed as the outcome of the study and its application under the joint crediting mechanism is not officially approved.

(1) Eligibility criteria

Although the Project targets specific business-use facilities as described above, chillers for air conditioning systems are widely used at other business-purpose buildings and plants and their replacement, which includes recovery and destruction of fluorocarbons as refrigerant, can happen in other sectors. Thus, the requirements were examined without limiting the use and characteristics of the target facility so they can be applied to plants of other sectors.

Possible eligibility criterias include the following:

- Criteria 1: Chiller for the air conditioning system, which consumes electricity only
- Criteria 2: It is the replacement of existing facility.
- Criteria 3: Electricity supplied to the reference and project chillers is grid power from a power company in the country.
- Criteria 4: Power consumption data for one year before the project implementation of the chiller subject to the replacement can be obtained.

Inclusion of another requirement that the fluorocarbons contained as the refrigerant be the substance designated under the Kyoto Protocol was also considered as a eligibility criteria. However, as it is pointed out in the Montreal Protocol, the proper recovery and destruction is meaningful even they are not substances designated by the Kyoto Protocol (HCFC, etc.). Thus, it was decided that it is not included as a requirement herein and that it is treated as CO-Benefit.

(2) Reduction volume calculation method (proposal)

The reference emissions (REy) and project emissions (PEy) in Year “y” are propose to be estimated based on the following formula:

$$REy = EC_{RE} \times EFy$$

$$EC_{REy} = EC_m \times H_y / H_m$$

EC_{REy} : reference power consumption in Year y [kWh/y]

EC_{REm} : actually measured power consumption of reference in the monitoring year [kWh/y]

H_y : chiller operation hours in Year y [hrs/y]

H_m : actually measured operation hours in the monitoring year [kWh/y]

EF : emission factor of grid power of the target country in Year y [t-CO₂/kWh]

$$PEy = REy \times R\eta / P\eta$$

$R\eta$: efficiency of reference chiller (coefficient of performance)

$P\eta$: efficiency of project chiller (coefficient of performance)

The destruction effects of fluorocarbons designated under the Kyoto Protocol, contained as the refrigerant of the project chiller, are not included herein. The calculation methods are examined later separately.

6.2 Evaluation methods of fluorocarbon destruction effects

The evaluation method of destruction efficiency of fluorocarbons presented in the survey results in Thailand is used.