


○ Overview

|   |   |
|---|---|
| Target verification technology/Environmental technology developer | Membrane separation activated sludge method / KUBOTA Corporation  |
| Verification organization (executing the test)                    | Kagawa Prefectural Government<br>(Kagawa Prefectural Research Institute for Environmental Science and Public Health, Shikoku Instrumentation CO., LTD.) |
| Verification test period  | September 24, 2004 through February 18, 2005  |
| Objective of this technology                                      | General treatment of organic wastewater   |

1. Summary of target verification technology



2. Summary of the verification test

○ Summary of the verification-test site









|  |  |
|--|--|
| Type of business establishment                           | Production of soy sauce                          |
| Scale of business establishment                          | Soy sauce production of 300 KL/month             |
| Location of site   | 5379 Fuchuu-cho, Sakaide City, Kagawa Prefecture |
| Amount of wastewater during the verification-test period |  |

○ Specifications and processing capacity of the target verification apparatus

| Division             | Item                         | Specifications and processing capacity  |
|----------------------|------------------------------|---|
| Outline of apparatus | Model                        | Activated sludge method water treatment apparatus (a membrane pack/MT60 is used in the water) |
|                      | Dimensions and weight        | W12,700mm × D12,400mm × H2,854mm, Approx. 15,000 kg   |
| Design conditions    | Target substances            | BOD, SS   |
|                      | Daily wastewater flow rate   | 35 m³/day   |
|                      | Influent-wastewater quality  | (BOD)400 mg/L, (SS)950 mg/L, (pH)5.8 - 8.6  |
|                      | Processed wastewater quality | (BOD)10 mg/L, (SS)5 mg/L, (pH)5. - 8.6  |

○ Verification items concerning water quality

| Item   | Unit | Verification results (Lower adjacent value through upper adjacent value, and median) |      |                 |      |
|--------|------|--|------|-----------------|------|
|        |      | Influent water   |      | Processed water |      |
| pH*    | -    | 5.4 - 7.9  | 6.6  | 7.4 - 8.0       | 7.6  |
| BOD    | mg/L | 430 - 1,400  | 1100 | <0.5 - 1.5      | 1.0  |
| COD*   | mg/L | 350 - 1,200  | 570  | 10 - 23         | 13   |
| SS     | mg/L | 210 - 770  | 420  | <0.5 - <0.5     | <0.5 |
| n-Hex* | mg/L | 18 - 620   | 200  | <1.0 - <1.0     | <1.0 |
| T-N*   | mg/L | 35 - 78  | 56   | 0.8 - 3.1       | 1.6  |
| T-P*   | mg/L | 6.2 - 17   | 10   | 0.01 - 0.17     | 0.03 |



Note 1: The removal rates are calculated from the results of periodical tests. Removal rate = (Total pollution load of influent water – Total pollution load of processed water)/ Total pollution load of influent water

Note 2: Items marked with \* are excluded from the target items which this particular target verification apparatus is assumed to remove

Note 3: Number of influent water data = 23 Number of processed water data=23. However, there are data which do not involve flow rate measurements; the number of influent water data is 19 and the number of processed water data is 19 for the calculation of the removal rate.

○ Items concerning environmental impact

| Item                       | Verification results  |
|----------------------------|---|
| Amount of generated sludge | 8.9kg/day(dry), 60.6kg/day(water content 85.3%)   |
| Amount of generated waste  | Screen residues: 0.3 kg/day (dry) and 2.0 kg/day (water content: 84.0%)   |
| Noise                      | 65.3 dB(including environmental noise other than the facilities)  |
| Odor                       | Odor index: 14 Odor concentration: 23 Odor intensity: 3 (six grade odor intensity measurement method)<br>Odor offensiveness: 0 (nine grade odor offensiveness measurement method) |


○ Items concerning used resources

| Item   | Verification results  |
|--|---|
| Electricity consumption                            | 128kWh/day  |
| Consumption of wastewater treatment chemicals, etc | Ferric chloride solution: 3.5 kg/day  |
| Consumption of other materials                     | Membrane cleaning chemicals<br>Oxalic acid: 4.7 kg/year<br>12% sodium hypochlorite: 38 kg/year  |
|  | Membrane equipment consumables<br>Replenishment of membrane cartridges (Replacement was not conducted during the verification test period.) |

○ Items concerning operation and maintenance performance

| Maintenance item         | Maintenance time and frequency  | Number of operators and level of operator expertise required for maintenance |
|--------------------------|---|--|
| Daily inspection         | 10 min (Once a day)   | One operator. No particular expertise is required.                           |
| Removal of excess sludge | 30 min (a few times per week)<br>2 to 4 removals per month can be applied if a sludge storage tank is used. | One operator. No particular expertise is required.                           |
| Membrane cleaning        | 180 min (twice a year)  | One operator. No particular expertise is required.                           |

○ Qualitative findings

| Item  | Findings   |
|---|--|
| Water quality findings  | Influent water : Brown with some turbidity<br>Processed water: Light brown and transparent<br>(Measured on Feb. 18, 2005)<br><br>Influent water    Processed water   |
| Period required for startup of the target verification apparatus  | Not verified, because the facilities had been operated.  |
| Period required for stoppage of the target verification apparatus | Not verified, because the facilities had been operated.  |
| Reliability of the target verification apparatus                  | Stable during the verification test period. However, the operation was interrupted once as the facilities were flooded by the typhoon.   |
| Restoring from a trouble state                                    | Operational failures may be restored in accordance with the Operating Manual and Maintenance Manual. However, troubles with the membrane must be solved by a special servicing establishment.  |
| Evaluation of O&M instruction manual                              | Nothing in particular needs to be improved.  |
| Others  | ○ The high-grade quality of the processed water, which can be reused, is maintained.<br>○ A remote-controlled monitoring system is provided within the facilities and the special servicing establishment is responsible for checking the operating conditions twice a day and notifying and restoring the system in the event of failure. |

(Information for reference)

The information provided on this page has been submitted by the environmental technology developer, who is solely responsible for its contents. Neither the Ministry of the Environment nor the Verification Organization may be held responsible for the information.

○ Product Data

| Item   |  | Information provided by environment technology developer   |   |            |
|--|--|--|---|------------|
| Name/Model No.                               |  | Activated sludge method water treatment apparatus<br>(membrane pack/MT60 is used in the water)     |   |            |
| Name of manufacturer<br>(distributor)        |  | KUBOTA Corporation   |   |            |
| Contact<br>address                           | TEL/FAX  | TEL : 03-3245-3665 (+81-3-3245-3665)<br>FAX : 03-3245-3407 (+81-3-3245-3407)                       |   |            |
|  | E-mail   | —  |   |            |
| Dimensions/Weight                            |  | W 4,212mm×D 2,202 mm×H 2,854 mm 4,000kg  |   |            |
| Necessity for pre- and/or<br>post-treatment  |  | Not required(Required depending upon the raw water quality)  |   |            |
| Additional equipment                         |  | A raw water tank and flow rate adjustment tank are required.                                       |   |            |
| Lifespan of target<br>verification apparatus |  | About 15 years (depending on the maintenance condition)<br>3 to 7 years for the membrane cartridge |   |            |
| Startup period                               |  | 1day   |   |            |
| Approximate cost<br>(yen)                    | Item   | Unit price   | Qty.  | Total      |
|  | Initial cost<br>(excluding the construction work<br>of additional facilities)                                      |  |   | 14,685,000 |
|  | Main unit and installation<br>work   |  | One set                                       | 12,800,000 |
|  | Remodeling of existing<br>wastewater facilities  |  | One set                                       | 1,850,000  |
|  | Other expenses   |  | One set                                       | 35,000     |
|  | Running cost (monthly)   |  |   | 204,090    |
|  | Sludge treatment cost  | 23,000yen/m <sup>3</sup>   | 1.8 m <sup>3</sup>                            | 41,400     |
|  | Waste treatment cost   | 23,000yen/ m <sup>3</sup>  | 0.06 m <sup>3</sup>                           | 1,380      |
|  | Electricity consumption  | 15yen/kWh  | 3,840kWh                                      | 57,600     |
|  | Water consumption  | -----  | -----   | -----      |
|  | Water treatment chemical cost  | 67yen/ kg  | 110kg   | 7,370      |
|  | Other consumables  |  |   | 96,340     |
|  | Membrane cleaning<br>chemical cost<br>Oxalic acid and sodium<br>hypochlorite                                       |  | One set<br>One set (annual<br>cost/12 months) | 340        |
|  | Membrane equipment<br>consumables maintenance<br>contract (including one<br>special inspection once a<br>year)     |  | One set                                       | 96,000     |
|  | Maintenance commissioning<br>cost  | -----  | -----   | -----      |
|  | Per 1 m <sup>3</sup> of processed wastewater (Processed wastewater is<br>assumed to be 700 m <sup>3</sup> /month.) |  |   | 292        |

○ Miscellaneous information provided by the manufacturer

- The proliferation of filamentous bacteria or bulking specific to the activated sludge method does not affect the quality of the processed water.
- The apparatus can be installed additionally to the existing treatment system with ease and the changeover operation can be quickly accomplished.
- A remote-controlled monitoring system is provided as standard, operating conditions can be checked via telephone line from a distance.