


O Overview	The copy	pyright of this verification experiment report is owned by the Ministry of the Environment.				
Technology intended for verification / environmental technology developer		GT OVAL system / BEST PLAN Co.,Ltd.				
Demonstration institution		Saitama-ken Environmental Analysis & Research Association				
Period of the experiment for verification		December 8, 2010 to December 9, 2010^{*1}				
Purpose of this technology		Pollutants in wastewater discharged from the kitchen were decomposed by enzyme through aeration. This technology is designed to rmove oil and fat accumulated in greasetrap and to improve odor. However, this technology operates as an aerator while the discharge of wastewater is stopped from when the day's work is finished until the next day's work is started.				

*1: For verification test period, see the main section in the detailed part.



*3 : UE is made from the sugars and extracts of tropical fruits such as pineapple.



2. Outline of the verification experiment

(1) Outline of the location for performing the verification experiment									
Project type and scal	School cafeteria, Total floor area : $500m^2$ • Number of seats : 350								
Name / Address	Shukutoku university Mizuhodai Campus • 1150-1, Fujikubo, Miyoshi-machi Iruma-gun, Saitama								
Influent quantity into the equipment intended for verification ^{*4} (Box plot ^{*5})	Influent quantity Average 7.67 m^3 /day 0.0 1.0 2.0 3.0 4.0 (m ³ /h)								

*4 : This indicates the volume of influent entering the grease trap.

*5 : For the box plot, see "How to Read the Box Plot" (for Reference) (Page 35 of the main section in the detailed part).

(2) Specification and performance of the equipment used for verification
--

Category	Item	Specifications and water treatment capacity					
	Model	GT OVAL system	GT OVAL system				
Outline of the facility	Size and weightMagical Cleaner 2 and aerator Capacity of grease trap: 0.288 m^3 (length $1.2 \text{ m} \times \text{width } 0.6 \text{ m} \times \text{depth } 0.4 \text{ m}$)						
	Object Water treatment	Biochemical oxygen demand (BOD)	Suspended solids (SS)				
Design	capacity per a day	Chemical oxygen demand (COD)	n-hexane extract content (n-Hex)				
conditions Category	Treatment object	Treatment is performed by the grease trap $(0.288 \text{ m}^3 \text{ capacity})$ combination with aeration.					
	Item	0	D, COD and n-Hex is 60% or more. as 70% or more				

3. Results of the verification experiment

3.1 The water quality verification items of the daily water quality tests (For the weekly water quality test, see the Main Part in the Detailed Version.)

The verification items of the daily water quality tests (conducted from Dec. 8, 2010 to Dec. 9, 2010) are shown in the following Tables (1) and (2). Table (1) shows the water quality concentration during and before aeration. "15:00*" indicates the concentration before treating the wastewater, and "9:00 next morning*" is after treating the wastewater. Table (2) shows the reduction ratio found from the water concentration at 15:00 (10 minutes after the influent was stopped and the aeration was started) and at 9:00 the next morning (after aeration of 18 hours and 30 minutes). This average reduction ratio for the water quality concentration is not based on the total influent volume (daily average of 7.67 m³), but instead is based on the wastewater (0.288 m³) in the grease trap, in which the influent contaminants, except soluble substances, are concentrated.



①:Water quality concentration during and before aeration in the daily water quality test(Unit: mg/L)																								
Test schedule		Was	stewater treatment	BOD		COD		SS		n-Hex														
		details/ water sampling location ^{*1} Sampling time		Influent	Third chamber ^{*1}	Influent	Third chamber ^{*1}	Influent	Third chamber ^{*1}	Influent	Third chamber ^{*1}													
		(i)	14:30	-	816	_	330	-	787	_	320													
	Day		The diluted solut	ion of "N	Iagical C	leaner 2"	is added.	(Diluted	influent	is present) ^{*2}													
	1 ^{*3}		15:00*	-	715	-	275	_	590	_	220													
		(ii)	Next morning 9:00*	-	217	_	93.3	_	60	_	58													
the daily				Influent	effluent	Influent	effluent	Influent	effluent	Influent	effluent													
water			9:00 ^{*4}	-	(217)	-	(93.3)	-	(60)	-	(58)													
quality																9:00~10:00	96.4	150	39.0	63.7	37	41	11	43
tests					10:00~11:00	110	67.8	76.1	38.6	27	28	5	6											
	Day 2	(iii)	11:00~12:00	194	184	132	110	63	60	21	20													
			12:00~13:00	242	218	174	121	71	71	23	29													
			13:00~14:00	636	524	407	297	211	143	98	97													
			14:00~15:00 ^{*2}	336	391	244	248	97	142	72	85													

2:Reduction ratio of the water quality concentration in the wastewater during aeration on the first day of the daily water

quality test

	W	astewater	BOD		COD (Mn)		SS		n-Hex	
the daily water quality	treatment details/ water sampling location ^{*1} Sampling time		Treated wastewater (mg/L)	Reducing rate (%)	Treated wastewater (mg/L)	Reducing rate (%)	Treated wastewater (mg/L)	Reducing rate (%)	Treated wastewater (mg/L)	Reducing rate (%)
tests Day 1 ^{*3}		15:00*	715	_*5	275	_*5	590	_*5	220	_ ^{*5}
Day 1	(ii)	Next morning 9:00*	217	69.7	93.3	66.1	60	89.8	58	73.6


*1: (i), (ii) and (iii) in the "wastewater treatment details/water sampling location" are as follows. "3rd chamber" in the table indicates the third chamber of the grease trap (see Figure 4-2 on Page 18 of the Main Part in the Detailed Version).

- (i) There is no influent while aeration is performed for agitation. The treated wastewater is sampled in the third chamber of the grease trap.
- (ii) There is no influent during the aeration process. The treated wastewater is sampled in the third chamber.
- (iii) This stage is before starting aeration, when influent is present. The influent is sampled in the influent inlet of the grease trap. The effluent is sampled by siphon in the grease trap's third chamber (outlet of the effluent).
- *2 : For details on the diluted solution of "Magical Cleaner 2", see Table 4-3 (on Page 16 of the Main Part in the Detailed Version). On the second day of the daily water quality test, the diluted solution of "Magical Cleaner 2" was injected at the same hour as on the first day and was present in the wastewater when each water quality concentration was measured.
- *3 : The daily water quality test on the first day was ended at 9:00 the next morning.
- *4 : Measurement of the effluent in the daily water quality test on the second day was started at 9:00 the next morning when the treated wastewater was measured.
- *5 : Although the water quality concentration of the effluent was measured at 14:30, the treated wastewater within the grease trap was diluted when the diluted solution of "Magical Cleaner 2" was injected. Therefore, for calculating the reduction ratio in the water quality concentration, the concentration at 14:30 was excluded from Table 6-3 (Page 32 of the Main Part in the Detailed Version) and the reduction ratio between 14:30 and 15:00 was not determined.



3.2 Change in volume of influent entering the grease trap and each water quality concentration in the daily water quality test

The following graph shows the change in volume of the influent entering the grease trap and each water quality concentration in the daily water quality test. The same time axis is used for the influx volume and each water concentration. In addition, Magical Cleaner 2 (150 ml) is diluted in the solution (0.221 m³) and injected into the grease trap from the washing sink. This diluted solution accounts for 77% of the grease trap capacity (0.288 m³). For the weekly water quality test, see the Main Part in the Detailed Version.



3.3 Operation and maintenance item

(1) Environmental impact item							
Amount of sludge	No waste is generated in the wastewater treatment process. However, it is necessary to remove the oil globules and food residue from the strainer in the grease trap.						
Noise	No abnormal noise was found compared with the surrounding noise (exhaust fans, etc.) in the kitchen.						
Odor	In the organoleptic examination, when the exterior unit of the grease trap was normally used (when the grease trap lid was closed), the odor index was less than 10, the odor concentration was also less than 10, and we confirmed the absence of any unpleasant odors. Within the grease trap, the odor index was reduced to about 2/3 and the odor concentration was reduced to about 1/20 after the wastewater was treated.						

(2) Used resources index

consumable stores	A total of 150 ml of Magical Cleaner 2 was used in four washing sinks a day.
Amount of electric	Only the air pump used electric power, and the power usage was only 2.21 kW/day in
energy used	the weekly water quality test.


(3) Operation and maintenance performance item

Maintenan ce item	Maintenance time per operation and maintenance frequency	Number of people and skill required for maintenance
Daily check	Magical Cleaner 2 is injected when the kitchen work is finished every day.	One person without any special skills is required.
Periodic check	 If a failure occurs, our engineer will fix it. Check the operation of the air pump and the timer setting. Remove the oil globules and food residue from the strainer in the grease trap about twice every month. 	No periodic inspection was required during the verification test period.


(4)Qualitative remark

Remark on water quality(sampled wastewater)

In the wastewater treatment using this technology, sediment was found before treating the wastewater, but almost no sediment was found after injecting Magical Cleaner 2 and aerating the wastewater for 18 hours and 30 minutes (daily water quality test).



grease trap at 15:00.



After injecting Magical Cleaner 2 and aerating the wastewater in the third chamber of the grease trap for 18 hours and 30 minutes, the water was sampled at 9:00 the next morning.



(4) Qualitative remark(continuation)

(d						
Remark on water Before the de	evice was installed After the device was installed (after aeration of 18 hours and 30 minutes)					
Terms required for initiation	It is only necessary to set the timer to operate the air pump during the time from stopping the discharge of wastewater from the kitchen until restarting the discharge of wastewater the next morning.					
Terms required for shutdown	The operation can be stopped immediately just by turning off the switch for the aerator after stopping the injection of Magical Cleaner 2.					
Daily check • Periodic check	 Basically, it is only necessary to inject Magical Cleaner 2 when the day's work is finished. The air pump for the aerator of the device can be operated automatically by setting the timer, eliminating the need for daily manual operation. It is necessary to open the grease trap lid and remove the accumulated oil globules and food residue from the strainer in the grease trap about twice every month. 					
Reliability of the equipment intended for verification	No trouble occurred in the verification equipment during the experiment.					
How to solve the problems	If the air pump fails or any other problem occurs, the applicant for verification will fix it.					
Evaluation of the instruction manual of operation and maintenance	The instruction manual for operation and maintenance was easy to understand.					
Others	Since the contaminants in the wastewater can be effectively removed repeatedly and odors are reduced, this device is well-suited for pretreatment of wastewater.					



4. Reference information

The information shown on this page is provided by the applicant for verification at its responsibility for publication of the technical data and not the subject of the verification experiment. The Ministry of the Environment and the organization conducting the verification experiment are not responsible for the information on this page.

O Product date (reference information)

Items		Column to be filled in by the applicant for verification							
Name/type		GT OVAL system							
Ma	anufacturer		BEST	Γ PLAN Co.,Ltd.					
	TEL/FAX		TEL088 (653) 0317 / FAX 088 (652) 7390						
Contact address	Web address		http://w	ww.bestplan-t.com	1/				
	E-mail		info	@bestplan-t.com					
-	of for pre-treatment			None					
Suppler	mentary facility		If no power supply is availa	ble, electrical worl	k must be per	formed.			
Life of	the equipment		Six years for th	e body and the driv	ving unit				
Time	for initiation		The equipment can be	used immediately a	after installat	ion.			
			Expense item	Unit price	Quantity	Total			
		I	Initial cost						
			Body type	252,000 yen	1 set	252,000 yen			
			Delivery cost	840 yen/piece	2 set	1,680 yen			
			Installation work	To be quoted	1 set	21.500			
			(Basic 31,500 yen)	separately		31,500 yen			
Appr	oximate cost		Total		1 set	285,180 yen			
r ippi	oximate cost	Running cost (monthly)							
			Electric power consumption (To be operated on holidays also)	30 yen/kW	66.3 kW^{*2}	1,989 yen			
			consumable stores (Magical Cleaner 2) ^{*3}	10,000 yen/2L	$1.26 L^{*4}$	6,300 yen			
			 Cost for treating wastewater^{*5}: ¥1,370/m³ Breakdown (electric power: ¥329 Magical Cleaner 2: ¥1,041) Cost per day: ¥366 Breakdown (¥1,989/30 days Magical Cleaner 2: ¥6,300/21 days) 						

*1:The number of days for operating the kitchen was calculated as 21 days a month.

*2:Power usage per month = 2.211 kW (daily power usage^{*6}) \times 30 days

*3:The price of a 2-liter bottle of Magical Cleaner 2 is ¥10,000.

*4:Monthly usage of Magical Cleaner 2 = 60 ml (volume per day recommended by the applicant for verification) \times 21 days = 1.26 L

*5:Monthly treated water volume = 0.288 m^3 (daily treated water volume: grease trap capacity) $\times 21 \text{ days} = 6.05 \text{ m}^3$

*6:Quoted from Table 6-9 (on Page 41 of the Main Part in the Detailed Version)



O Other information from the manufacturer (reference information)

- •This system decomposes fats and organic sludge by using an emulsifier, which mainly consists of the patented special enzyme and the fat extracted from several plants, in combination with an aerator.
- Since the system uses 100% natural materials, its environmental load is very low.
- This system was delivered through Gakken Holdings Co., Ltd. to more than 500 nursery schools across the country. It was introduced by the Kansai University CO-OP and is currently used by more than 15 national, public and private universities in the Kansai region. In addition, it is used by several cafeterias of the prefectural governments in the Chugoku and Shikoku regions and by a large supermarket chain of stores in the Kansai region. It has also been introduced by more than 2,000 hospitals, geriatric health service facilities, primary schools and school lunch centers across the country.
- •Many of the users of this system say that "There are no more bad smells from the grease trap or having to clean it", "The piping no longer becomes clogged" and "There is almost no slime due to wastewater".

• This system not only cleans the grease trap, a part of the system, but it cleans the entire drainage system in the kitchen.