

放射性物質濃度測定結果記録 3月分

測定日	測定項目																										
	焼却主灰中放射性物質濃度(Bq/kg)									焼却飛灰中放射性物質濃度(Bq/kg)									焼却炉排ガス中放射性物質濃度(Bq/m <sup>3</sup> )								
	1号炉			2号炉			3号炉			1号炉			2号炉			3号炉			1号炉			2号炉			3号炉		
	<sup>134</sup> Cs	<sup>137</sup> Cs	合計	<sup>134</sup> Cs	<sup>137</sup> Cs	合計	<sup>134</sup> Cs	<sup>137</sup> Cs	合計	<sup>134</sup> Cs	<sup>137</sup> Cs	合計	<sup>134</sup> Cs	<sup>137</sup> Cs	合計	<sup>134</sup> Cs	<sup>137</sup> Cs	合計	<sup>134</sup> Cs	<sup>137</sup> Cs	合計	<sup>134</sup> Cs	<sup>137</sup> Cs	合計	<sup>134</sup> Cs	<sup>137</sup> Cs	合計
1	200	340	540	200	350	550	180	340	520	1,240	2,300	3,540	1,220	2,350	3,570	710	1,340	2,050	ND	ND	ND	ND	ND	ND	ND	ND	ND
2	210	400	610	180	320	500	130	240	370	1,080	2,100	3,180	1,170	2,250	3,420	810	1,450	2,260	ND	ND	ND	ND	ND	ND	ND	ND	ND
3	210	450	660	210	400	610	170	300	470	840	1,540	2,380	780	1,530	2,310	920	1,740	2,660	ND	ND	ND	ND	ND	ND	ND	ND	ND
4	200	420	620	250	460	710	190	320	510	990	1,900	2,890	770	1,480	2,250	930	1,850	2,780	ND	ND	ND	ND	ND	ND	ND	ND	ND
5	250	490	740	210	450	660	200	370	570	920	1,800	2,720	910	1,870	2,780	780	1,550	2,330	ND	ND	ND	ND	ND	ND	ND	ND	ND
6	180	370	550	280	510	790	160	310	470	950	1,850	2,800	830	1,610	2,440	960	1,820	2,780	ND	ND	ND	ND	ND	ND	ND	ND	ND
7	260	450	710	240	450	690	200	380	580	830	1,470	2,300	580	1,100	1,680	790	1,550	2,340	ND	ND	ND	ND	ND	ND	ND	ND	ND
8	220	390	610	280	530	810	220	380	600	800	1,550	2,350	570	1,160	1,730	800	1,480	2,280	ND	ND	ND	ND	ND	ND	ND	ND	ND
9	410	800	1,210	240	450	690	240	480	720	860	1,610	2,470	1,160	2,150	3,310	780	1,410	2,190	ND	ND	ND	ND	ND	ND	ND	ND	ND
10	220	460	680	250	500	750	220	400	620	1,250	2,380	3,630	960	1,830	2,790	860	1,720	2,580	ND	ND	ND	ND	ND	ND	ND	ND	ND
11	250	490	740	290	520	810	230	450	680	1,200	2,390	3,590	980	1,890	2,870	750	1,370	2,120	ND	ND	ND	ND	ND	ND	ND	ND	ND
12	170	350	520	290	600	890	280	430	710	1,170	2,190	3,360	930	1,770	2,700	730	1,410	2,140	ND	ND	ND	ND	ND	ND	ND	ND	ND
13	250	440	690	240	480	720	210	400	610	1,100	2,120	3,220	1,130	2,150	3,280	930	1,730	2,660	ND	ND	ND	ND	ND	ND	ND	ND	ND
14	250	430	680	230	460	690	180	370	550	1,040	2,030	3,070	1,190	2,210	3,400	690	1,300	1,990	ND	ND	ND	ND	ND	ND	ND	ND	ND
15	290	550	840	250	530	780	170	360	530	940	1,850	2,790	1,200	2,240	3,440	850	1,660	2,510	ND	ND	ND	ND	ND	ND	ND	ND	ND
16	190	360	550	260	490	750	180	360	540	980	1,970	2,950	1,000	2,000	3,000	640	1,240	1,880	ND	ND	ND	ND	ND	ND	ND	ND	ND
17	210	410	620	210	420	630	170	310	480	1,080	2,050	3,130	1,160	2,280	3,440	660	1,310	1,970	ND	ND	ND	ND	ND	ND	ND	ND	ND
18	190	350	540	200	390	590	180	340	520	1,350	2,500	3,850	1,240	2,350	3,590	780	1,480	2,260	ND	ND	ND	ND	ND	ND	ND	ND	ND
19	230	440	670	220	400	620	240	440	680	1,340	2,590	3,930	1,330	2,620	3,950	630	1,250	1,880	ND	ND	ND	ND	ND	ND	ND	ND	ND
20	260	500	760	250	510	760	190	380	570	1,210	2,320	3,530	1,270	2,420	3,690	660	1,160	1,820	ND	ND	ND	ND	ND	ND	ND	ND	ND
21	310	640	950	350	650	1,000	240	410	650	1,250	2,430	3,680	1,250	2,480	3,730	640	1,290	1,930	ND	ND	ND	ND	ND	ND	ND	ND	ND
22	220	450	670	320	620	940	340	670	1,010	1,250	2,500	3,750	1,150	2,160	3,310	610	1,190	1,800	ND	ND	ND	ND	ND	ND	ND	ND	ND
23	340	670	1,010	410	810	1,220	340	640	980	1,270	2,540	3,810	1,200	2,320	3,520	910	1,760	2,670	ND	ND	ND	ND	ND	ND	ND	ND	ND
24	200	400	600	200	370	570	320	600	920	1,400	2,750	4,150	1,420	2,780	4,200	1,040	2,040	3,080	ND	ND	ND	ND	ND	ND	ND	ND	ND
25	170	350	520	220	400	620	200	380	580	1,420	2,810	4,230	1,290	2,570	3,860	910	1,690	2,600	ND	ND	ND	ND	ND	ND	ND	ND	ND
26	180	330	510	180	320	500	160	290	450	1,600	3,010	4,610	1,460	2,920	4,380	840	1,580	2,420	ND	ND	ND	ND	ND	ND	ND	ND	ND
27	170	330	500	180	330	510	200	400	600	1,580	2,980	4,560	1,540	3,000	4,540	890	1,770	2,660	ND	ND	ND	ND	ND	ND	ND	ND	ND
28	190	360	550	170	360	530	150	270	420	1,960	3,710	5,670	1,830	3,730	5,560	950	1,760	2,710	ND	ND	ND	ND	ND	ND	ND	ND	ND
29	210	420	630	180	360	540	180	360	540	1,880	3,650	5,530	1,950	3,860	5,810	960	1,870	2,830	ND	ND	ND	ND	ND	ND	ND	ND	ND
30	190	370	560	160	300	460	150	240	390	1,800	3,500	5,300	2,060	4,020	6,080	750	1,470	2,220	ND	ND	ND	ND	ND	ND	ND	ND	ND
31	190	370	560	160	270	430	170	350	520	2,040	3,880	5,920	1,920	3,780	5,700	1,030	2,070	3,100	1.2.3号炉立下げの為、未測定								

(ND:検出下限値[ろ紙部、ドレン部のセシウム134、セシウム137濃度が各2Bq/m<sup>3</sup>(N)]未満)