

H26年 3月放射性物質濃度測定結果

測定日	測定項目																										
	焼却主灰中放射性物質濃度(Bq/kg)									焼却飛灰中放射性物質濃度(Bq/kg)									焼却炉排ガス中放射性物質濃度(Bq/m ³)								
	1号炉			2号炉			3号炉			1号炉			2号炉			3号炉			1号炉			2号炉			3号炉		
	¹³⁴ Cs	¹³⁷ Cs	合計	¹³⁴ Cs	¹³⁷ Cs	合計	¹³⁴ Cs	¹³⁷ Cs	合計	¹³⁴ Cs	¹³⁷ Cs	合計	¹³⁴ Cs	¹³⁷ Cs	合計	¹³⁴ Cs	¹³⁷ Cs	合計	¹³⁴ Cs	¹³⁷ Cs	合計	¹³⁴ Cs	¹³⁷ Cs	合計	¹³⁴ Cs	¹³⁷ Cs	合計
1	-	-	-	300	700	1,000	290	800	1,090	-	-	-	640	1,650	2,290	-	-	-	-	-	-	ND	ND	ND	ND	ND	ND
2	-	-	-	310	790	1,100	660	1,830	2,490	-	-	-	680	1,720	2,400	2,100	5,280	7,380	-	-	-	-	-	-	ND	ND	ND
3	-	-	-	300	770	1,070	450	1,220	1,670	-	-	-	550	1,530	2,080	2,110	5,360	7,470	-	-	-	-	-	-	ND	ND	ND
4	-	-	-	270	690	960	530	1,310	1,840	-	-	-	540	1,450	1,990	1,730	4,540	6,270	-	-	-	-	-	-	ND	ND	ND
5	-	-	-	210	550	760	440	1,190	1,630	-	-	-	600	1,590	2,190	1,510	3,970	5,480	-	-	-	-	-	-	ND	ND	ND
6	-	-	-	260	690	950	380	910	1,290	-	-	-	440	1,160	1,600	2,210	5,680	7,890	-	-	-	-	-	-	ND	ND	ND
7	-	-	-	270	700	970	500	1,310	1,810	-	-	-	420	1,100	1,520	1,840	4,810	6,650	-	-	-	-	-	-	ND	ND	ND
8	-	-	-	190	500	690	360	920	1,280	-	-	-	320	820	1,140	2,260	5,810	8,070	-	-	-	-	-	-	ND	ND	ND
9	-	-	-	270	680	950	810	2,100	2,910	-	-	-	280	710	990	3,370	8,390	11,760	-	-	-	-	-	-	ND	ND	ND
10	-	-	-	270	670	940	420	1,080	1,500	-	-	-	350	930	1,280	2,610	6,680	9,290	-	-	-	-	-	-	ND	ND	ND
11	-	-	-	230	560	790	1,150	2,970	4,120	-	-	-	330	910	1,240	3,560	9,070	12,630	-	-	-	-	-	-	ND	ND	ND
12	-	-	-	190	510	700	1,060	2,770	3,830	-	-	-	530	1,410	1,940	2,930	7,610	10,540	-	-	-	-	-	-	ND	ND	ND
13	-	-	-	150	380	530	860	2,220	3,080	-	-	-	490	1,300	1,790	2,200	5,660	7,860	-	-	-	-	-	-	ND	ND	ND
14	-	-	-	170	420	590	240	680	920	-	-	-	550	1,420	1,970	2,400	6,260	8,660	-	-	-	-	-	-	ND	ND	ND
15	-	-	-	-	-	-	720	1,830	2,550	-	-	-	-	-	-	2,180	5,520	7,700	-	-	-	-	-	-	ND	ND	ND
16	-	-	-	-	-	-	200	490	690	-	-	-	-	-	-	1,750	4,600	6,350	-	-	-	-	-	-	ND	ND	ND
17	-	-	-	-	-	-	710	1,880	2,590	-	-	-	-	-	-	2,670	6,980	9,650	-	-	-	-	-	-	ND	ND	ND
18	-	-	-	-	-	-	130	320	450	-	-	-	-	-	-	1,130	2,960	4,090	-	-	-	-	-	-	ND	ND	ND
19	-	-	-	-	-	-	130	360	490	-	-	-	-	-	-	550	1,420	1,970	-	-	-	-	-	-	ND	ND	ND
20	-	-	-	-	-	-	100	250	350	-	-	-	-	-	-	390	1,030	1,420	-	-	-	-	-	-	ND	ND	ND
21	-	-	-	-	-	-	100	270	370	-	-	-	-	-	-	460	1,230	1,690	-	-	-	-	-	-	ND	ND	ND
22	-	-	-	-	-	-	120	320	440	-	-	-	-	-	-	520	1,440	1,960	-	-	-	-	-	-	ND	ND	ND
23	-	-	-	-	-	-	120	280	400	-	-	-	-	-	-	640	1,700	2,340	-	-	-	-	-	-	ND	ND	ND
24	-	-	-	-	-	-	130	360	490	-	-	-	-	-	-	530	1,480	2,010	-	-	-	-	-	-	ND	ND	ND
25	-	-	-	-	-	-	140	400	540	-	-	-	-	-	-	620	1,660	2,280	-	-	-	-	-	-	ND	ND	ND
26	-	-	-	-	-	-	160	380	540	-	-	-	-	-	-	740	2,030	2,770	-	-	-	-	-	-	ND	ND	ND
27	-	-	-	-	-	-	130	360	490	-	-	-	-	-	-	690	1,910	2,600	-	-	-	-	-	-	ND	ND	ND
28	-	-	-	-	-	-	140	330	470	-	-	-	-	-	-	720	1,880	2,600	-	-	-	-	-	-	ND	ND	ND
29	-	-	-	-	-	-	170	450	620	-	-	-	-	-	-	920	2,350	3,270	-	-	-	-	-	-	ND	ND	ND
30	-	-	-	-	-	-	130	320	450	-	-	-	-	-	-	880	2,310	3,190	-	-	-	-	-	-	-	-	-
31	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-

特記事項 ※ 1日:3号炉バーナーストレーナー復旧後立上げ 14日:新地町災害廃棄物(可燃物)焼却処理完了
 ※30日:3号炉立下げ