

H26年8月放射性物質濃度等測定結果

測定日	測定項目								
	焼却主灰中放射性物質濃度 (Bq/kg)			焼却飛灰中放射性物質濃度 (Bq/kg)			焼却炉排ガス中放射性物質濃度 (Bq/m ³)		
	3号炉			3号炉			3号炉		
	¹³⁴ Cs	¹³⁷ Cs	合計	¹³⁴ Cs	¹³⁷ Cs	合計	¹³⁴ Cs	¹³⁷ Cs	合計
1	—	—	—	—	—	—	—	—	—
2	—	—	—	—	—	—	—	—	—
3	—	—	—	—	—	—	—	—	—
4	—	—	—	—	—	—	—	—	—
5	—	—	—	—	—	—	—	—	—
6	—	—	—	—	—	—	—	—	—
7	—	—	—	—	—	—	—	—	—
8	—	—	—	—	—	—	—	—	—
9	—	—	—	—	—	—	—	—	—
10	—	—	—	—	—	—	—	—	—
11	—	—	—	—	—	—	—	—	—
12	—	—	—	—	—	—	—	—	—
13	—	—	—	—	—	—	—	—	—
14	—	—	—	—	—	—	—	—	—
15	—	—	—	—	—	—	—	—	—
16	—	—	—	—	—	—	—	—	—
17	—	—	—	—	—	—	—	—	—
18	—	—	—	—	—	—	—	—	—
19	160	520	680	—	—	—	ND	ND	ND
20	150	450	600	470	1430	1900	ND	ND	ND
21	150	420	570	460	1320	1780	ND	ND	ND
22	240	610	850	370	1120	1490	ND	ND	ND
23	190	530	720	460	1350	1810	ND	ND	ND
24	110	410	520	410	1270	1680	ND	ND	ND
25	140	390	530	330	1030	1360	ND	ND	ND
26	170	450	620	750	2220	2970	ND	ND	ND
27	350	950	1300	350	1050	1400	ND	ND	ND
28	200	590	790	330	1090	1420	ND	ND	ND
29	170	500	670	430	1300	1730	ND	ND	ND
30	—	—	—	—	—	—	—	—	—
31	—	—	—	—	—	—	—	—	—
特記事項									